

## BMU Capability and Price Submission Report

This report constitutes the publication of Holding Payment rates and other information as required by Clause 4.1.3.13A of the Connection and Use of System Code. The contents of the report include

- i. the available Response volume in respect of each applicable User's BM Unit(s) as indicated by :
  - Maximum Primary Response at 0.2Hz, 0.5Hz, 0.8Hz deviation from System nominal frequency of 50Hz
  - The amount of de-load from MEL required to deliver the maximum Primary Response at 0.2Hz, 0.5Hz, 0.8Hz deviation from System nominal frequency of 50Hz
  - Maximum Secondary Response at 0.2/0.2Hz, 0.5/0.5Hz deviation from System nominal frequency of 50Hz ( NB : 0.2/0.2 Hz means the point on the Frequency Response matrix corresponding to 0.2Hz deviation under Primary Response and 0.2Hz deviation under Secondary Response).
  - The amount of de-load from MEL required to deliver the maximum Secondary Response at 0.2/0.2Hz, 0.5/0.5Hz deviation from System nominal frequency of 50Hz
  - Maximum High Frequency Response at 0.2Hz, 0.5Hz deviation from System nominal frequency of 50Hz
  - The amount of de-load from MEL required to deliver the maximum High Frequency Response at 0.2Hz, 0.5Hz deviation from System nominal frequency of 50Hz; and
- ii. The holding rates for Primary, Secondary and High Mandatory Frequency Response in respect of each applicable User's BM Unit(s) to apply in December 2005.

MW Response Capability by BMU

UNIT	Primary Response (Max MWhrs)				Secondary Response (Max Mwhrs)				High Frequency Response (Max					
	0.5Hz		0.8Hz		0.2/0.2Hz		0.5/0.5Hz		0.2Hz		0.5Hz			
ABTH7	40	250	72	250	72	250	48	250	120	250	38	185	55	185
ABTH8	40	250	72	250	72	250	48	250	120	250	38	185	55	185
ABTH9	40	250	72	250	72	250	48	250	120	250	38	185	55	185
BAGE-1	21	235	52	235	80	235	33	235	80	235	22	235	52	235
BAGE-2	3	17	8	17	12	17	4	17	9	17	2	17	5	17
BARBK2	30	215	63	215	72	215	36	215	67	215	33	69	69	23
BARK-1	20	145	42	145	48	145	24	145	58	145	22	145	42	145
BRGG-1	16	144	32	144	0	144	16	144	40	144	14	96	34	96
BRYP-1	15	82	25	82	31	82	22	82	37	82	10	82	27	47
CDCL-1	30	160	40	160	40	160	34	160	40	160	27	120	40	120
CLAC-1	3	37	6	37	6	37	3	37	8	37	3	30	30	30
CNOPS-1	22	126	51	126	70	126	28	126	70	126	20	100	45	100
CNOPS-2	22	126	51	126	70	126	28	126	70	126	20	100	45	100
CNOPS-3	22	126	51	126	70	126	28	126	70	126	20	100	45	100
CNOPS-4	22	126	51	126	70	126	28	126	70	126	20	100	45	100
COCK-1	15	168	42	168	48	168	10	168	25	168	6	138	7	138
COCK-2	15	168	42	168	48	168	10	168	25	168	6	138	7	138
COCK-3	15	168	42	168	48	168	10	168	25	168	6	138	7	138
COCK-4	15	168	42	168	48	168	10	168	25	168	6	138	7	138
CORB-1	18	60	34	60	40	60	22	60	39	60	22	24	40	0
COSD-1	24	323	44	323	48	323	46	323	110	323	28	258	42	258
COTPS-1	29	277	50	277	62	277	35	60	63	277	30	122	60	122
COTPS-2	29	287	50	287	62	287	35	60	63	287	30	122	60	122
COTPS-3	29	287	50	287	62	287	35	60	63	287	30	122	60	122
COTPS-4	29	277	50	277	62	277	35	60	63	277	30	122	60	122
CRUA-1	10	110	25	110	37	110	12	110	30	110	10	84	25	48
CRUA-2	10	110	25	110	37	110	12	110	30	110	10	84	25	48
CRUA-3	7	30	18	30	21	30	10	30	25	30	7	20	18	5
CRUA-4	7	30	18	30	21	30	10	30	25	30	7	20	18	5
DAMC-1	64	380	136	380	156	380	80	380	180	380	60	293	190	128
DEEP-1	20	180	60	180	86	180	22	180	80	180	24	96	52	96
DERW-1	13	90	35	90	45	90	16	90	40	90	16	90	32	72
DIDCB5	56	260	84	260	84	260	60	260	138	260	40	220	100	160
DIDCB6	64	203	120	203	120	203	60	203	100	203	68	115	130	73
DIDC1	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DIDC2	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DIDC3	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DIDC4	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DINO-1	14	138	39	138	58	138	28	138	72	138	14	118	36	88
DINO-2	14	138	39	138	58	138	28	138	72	138	14	118	36	88
DINO-3	14	138	39	138	58	138	28	138	72	138	14	118	36	88
DINO-4	14	138	39	138	58	138	28	138	72	138	14	118	36	88
DINO-5	14	138	39	138	58	138	28	138	72	138	14	118	36	88
DINO-6	14	138	39	138	58	138	28	138	72	138	14	118	36	88
DRAXX-1	68	345	100	345	100	345	64	95	110	345	60	225	70	225
DRAXX-2	68	345	100	345	100	345	64	95	110	345	60	225	70	225
DRAXX-3	68	345	100	345	100	345	64	95	110	345	60	225	70	225
DRAXX-4	68	345	100	345	100	345	64	95	110	345	60	225	70	225
DRAXX-5	68	345	100	345	100	345	64	95	110	345	60	225	70	225
DRAXX-6	68	345	100	345	100	345	64	95	110	345	60	225	70	225
ECL-1	20	133	25	133	25	133	25	133	25	133	25	105	40	105
EGGPS-1	45	205	83	205	83	205	49	205	110	205	33	95	60	95
EGGPS-2	45	205	83	205	83	205	49	205	110	205	33	95	60	95
EGGPS-3	45	205	83	205	83	205	49	205	110	205	33	95	60	95
EGGPS-4	45	205	83	205	83	205	49	205	110	205	33	95	60	95
ERR-1	1	21	1	21	1	21	2	21	5	21	1	17	1	17
ERR-2	1	21	1	21	1	21	2	21	5	21	1	17	1	17
ERR-3	1	21	1	21	1	21	2	21	5	21	1	17	1	17
FASN-1	0	15	1	15	1	15	1	15	2	15	0	15	1	12
FASN-2	0	15	1	15	1	15	1	15	2	15	0	15	1	12
FASN-3	0	15	1	15	1	15	1	15	2	15	0	15	1	12
FAWL1	36	244	77	244	77	244	10	244	10	244	40	98	91	145
FAWL3	36	244	77	244	77	244	10	244	10	244	40	98	91	145
FAWN-1	10	52	25	52	40	52	13	52	32	52	11	37	27	27
FELL-1	9	63	21	63	22	63	10	63	24	63	9	63	22	63
FERR-1	25	150	45	150	45	150	40	250	60	250	34	80	59	150
FERR-2	25	150	45	150	45	150	40	250	60	250	34	80	59	150
FERR-3	25	150	45	150	45	150	40	250	60	250	34	80	59	150
FERR-4	25	150	45	150	45	150	40	250	60	250	34	80	59	150
FFES-1	10	35	27	35	30	35	9	35	22	35	4	27	6	27
FFES-2	10	35	27	35	30	35	9	35	22	35	4	27	6	27
FFES-3	10	35	27	35	30	35	9	35	22	35	4	27	6	27
FFES-4	10	35	27	35	30	35	9	35	22	35	4	27	6	27
FIDL-1	13	205	20	205	23	205	35	100	40	147	30	147	50	147
FIDL-2	13	205	20	205	23	205	35	100	40	147	30	147	50	147
FIDL-3	13	205	20	205	23	205	35	100	40	147	30	147	50	147
FIDL-4	13	205	20	205	23	205	35	100	40	147	30	147	50	147
FINL-1	0	14	1	14	1	14	1	14	2	14	0	14	1	11
FOVE-1	6	60	13	60	16	60	11	60	27	60	5	30	11	30
FOVE-2	6	60	13	60	16	60	11	60	27	60	5	30	11	30
GRAI-1	43	485	100	485	160	485	60	485	140	485	33	0	60	345
GRAI-3	43	485	100	485	160	485	60	485	140	485	33	0	60	345
GRAI-4	43	485	100	485	160	485	60	485	140	485	33	0	60	345
GRM0-1	8	43	8	43	8	43	8	43	8	43	8	27	6	27
GRUB-1	0	6	0	6	0	6	0	6	1	6	0	6	0	6
GRUB-2	0	11	0	11	0	11	0	11	1	11	0	11	0	11
GYAR-1	17	176	42	176	66	176	24	176	60	176	17	176	42	176
HJMR-1	30	330	75	330	75	330	45	330	113	330	40	257	22	330
INDQ-1	12	102	31	102	43	102	13	102	34	102	12	72	30	72
IRNPS-1	35	125	45	125	48	125	42	285	68	125	28	125	42	185
IRNPS-2	35	125	45	125	48	125	42	285	68	125	28	125	42	185
KEAD-1	36	300	78	300	116	300	62	300	128	300	38	190	84	190
KILLPG-1	8	225	10	225	10	225	12	225	12	225	4	150	15	150
KILLPG-2	8	225	10	225	10	225	12	225	12	225	4	150	15	150
KILNS-1	30	290	72	290	84	290	42	290	114	290	18	104	15	290
KINO-1	32	115	60	255	70	255	27	255	50	255	27	115	55	65
KINO-2	32	115	60	255	70	255	27	255	50	255	27	115	55	65
KINO-3	32	115	60	255	70	255	27	255	50	255	27	115	55	65
KINO-4	32	115	60	255	70	255	27	255	50	255	27	115	55	65
KLYN-A-1	24	126	50	126	50	126	34	126	70	126	22	81	34	81
LBAR-1	40	230	64	230	66	230	60	230	132	230	36	120	86	120
LITTD1	57	485	110	485	110	485	66	485	80	485	60	335	150	335
LITTD2	57	485	110	485	110	485	66	485	80	485	60	335	150	335
LITTD3	57	485	110	485	110	485	66	485	80	485	60	335	150	335
LOAN-1	25	326	51	326	55	326	19	326	50	326	12	276		

Bmuname	Primary Price £/MW/h	Secondary £/MW/h	High Frequency £/MW/h
ABTH7	3.5	4	1.75
ABTH8	3.5	4	1.75
ABTH9	3.5	4	1.75
BAGE-1	2.52	2.92	0.75
BAGE-2	2.52	2.92	0.75
BARK-1	3.94	3.74	15
BARKB2	5	5	20
BRGG-1	50	50	50
Bryp-1	4	2	5
CDCL-1	3	3	20
CNQPS-1	3	1	13
CNQPS-2	3	1	13
CNQPS-3	4	2	14
CNQPS-4	4	2	14
COCK-1	5.9	5.9	1.22
COCK-2	5.9	5.9	1.22
COCK-3	5.9	5.9	1.22
COCK-4	5.9	5.9	1.22
CORB-1	8	2	10
COSO-1	4.31	4.31	3.01
COTPS-1	6.95	4.05	1
COTPS-2	1.75	2.75	7
COTPS-3	1.75	2.75	7
COTPS-4	1.75	2.75	7
CRUA-1	4.9	3.9	2
CRUA-2	4.9	3.9	2
CRUA-3	4.9	3.9	2
CRUA-4	4.9	3.9	2
DAMC-1	4.4	5.4	13
DEEP-1	7.9	3	6
DERW-1	5	5	15
DIDC1	5.5	1	2
DIDC2	5.5	1	2
DIDC3	5.5	1	2
DIDC4	5.5	1	2
DIDCB5	300	0	300
DIDCB6	8	0	12
DINO-1	4.9	3	9
DINO-2	4.9	3	9
DINO-3	4.9	3	9
DINO-4	4.9	3	9
DINO-5	4.9	3	9
DINO-6	4.9	3	9
DRAXX-1	2	5.27	6.73
DRAXX-2	2	5.27	6.73
DRAXX-3	2	5.27	6.73
DRAXX-4	2	5.27	6.73
DRAXX-5	2	5.27	6.73
DRAXX-6	2	5.27	6.73
EECL-1	3	1	16
EGGPS-1	2	4	9
EGGPS-2	2	4	9

EGGPS-3	2	4	9
EGGPS-4	2	4	9
ERRO-1	100	100	100
ERRO-2	100	100	100
ERRO-3	100	100	100
FASN-1	200	200	200
FASN-2	200	200	200
FASN-3	200	200	200
FAWL1	3.2	4.09	0.65
FAWL3	3.2	4.09	0.65
FAWN-1	5.68	0.58	1.37
FELL-1	1.9	1.9	0.44
FERR-1	5	4	14
FERR-2	5	4	14
FERR-3	5	4	14
FERR-4	5	4	14
FFES-1	4.9	3	9
FFES-2	4.9	3	9
FFES-3	4.9	3	9
FFES-4	4.9	3	9
FIDL-1	5	7	25
FIDL-2	4	3	14
FIDL-3	5	7	25
FIDL-4	5	7	25
FINL-1	50	50	50
FOYE-1	50	50	50
FOYE-2	50	50	50
GRAI-1	5	1	15
GRAI-3	5	1	15
GRAI-4	5	1	15
GRMO-1	100	100	100
GYAR-1	1	0	6.3
HUMR-1	150	150	150
INDQ-1	165	165	165
IRNPS-1	1.5	1.5	15.5
IRNPS-2	1.5	1.5	15.5
KEAD-1	5	4	14.5
KILLPG-1	3.5	3.5	10
KILLPG-2	3.5	3.5	10
KILNS-1	15.68	10.26	5.4
KINO-1	3.5	3	8
KINO-2	3.5	3	8
KINO-3	3.5	3	8
KINO-4	3.5	3	8
KLYN-A-1	9,999.00	9,999.00	9,999.00
LBAR-1	5.5	0	4.5
LITTD1	3.97	5.89	1.71
LITTD2	3.97	5.89	1.71
LITTD3	3.97	5.89	1.71
LOAN-1	5.71	5	1.22
LOAN-2	5.71	5	1.22
LOAN-3	5.71	5	1.22
LOAN-4	5.71	5	1.22
MEDP-1	4	3	13.5
NANT-1	75	75	75
PEHE-1	6	5	20

PEHE-2	6	7	20
PETEM1	4.5	2	7
RATS-1	5	2	10
RATS-2	5	2	10
RATS-3	5	2	10
RATS-4	5	2	10
ROCK-1	4.31	4.31	3.01
ROOS-1	22	14.4	12
RUGPS-6	3	2	9.5
RUGPS-7	3	2	9.5
RYHPS-1	4.4	5.4	13
SCCL-1	6.9	7.9	34.9
SCCL-2	3	4	17.9
SCCL-3	5	6	19.9
SEAB-1	5	7	35
SEAB-2	5	7	35
SHBA-1	5.5	2	12
SHBA-2	5	2	9
SHOS-1	4.4	5.4	13
SHOT-1	3.5	2	16
SIZB-1	25.63	43.18	42.65
SIZB-2	25.63	43.18	42.65
SLOY-1	100	100	100
SLOY-2	100	100	100
SLOY-3	100	100	100
SLOY-4	100	100	100
SPLN-1	14.99	14.99	14.99
SUTB-1	4.95	3.95	3.9
TESI-1	9,999.00	9,999.00	9,999.00
TESI-2	9,999.00	9,999.00	9,999.00
TILB10	2.66	3.55	1.56
TILB-7	2.66	3.55	1.56
TILB-8	2.66	3.55	1.56
TILB-9	2.66	3.55	1.56
USKM-13	2.21	1.94	0.59
USKM-14	2.21	1.94	0.59
USKM-15	2.21	1.94	0.59
WBUPS-1	1.8	2.8	7
WBUPS-2	1.8	2.8	7
WBUPS-3	1.8	2.8	7
WBUPS-4	1.8	2.8	7