

Generation Zoning

AEP offices London, 22nd August 2008

nationalgrid

Introduction

- ◆ Previous meeting (Meeting 8) – Presentation of zones using nodal exchange rates
 - ◆ Small zones
 - ◆ Unfavourable for TEC sharing or for use in other CUSC Amendment Proposals
- ◆ Zonal Alternative
 - ◆ Estimating consequences of using larger zones – short term indicative zones as base
 - ◆ Cost of constraint analysis
- ◆ Nodal Alternative

Cost of Constraint Analysis

- ◆ Divided into two components
 - ◆ Locational component
 - ◆ Utilisation component
- ◆ Previous analysis calculated headroom for each zone
 - ◆ Maximum transfer volume which causes minimal effect outside zone
- ◆ Repeated against full SQSS requirements
 - ◆ “Required transfer” condition at winter peak
- ◆ Cost of constraint estimates up to headroom comprises of utilisation component only
 - ◆ Effect of locational component anticipated to be minimal
- ◆ Beyond headroom – locational and utilisation components both significant

Locational and utilization component

- ◆ Locational component
 - ◆ Different location → different impact on circuit loadings
- ◆ Utilisation component
 - ◆ Refers to utilisation of long-term access rights

Assumptions 1

- ◆ SYS ranking order used to pick up the possible TEC donors and TEC recipients
 - ◆ No closures
 - ◆ Refinement to align with work on CAP164
 - ◆ SYS background up to 2012/13 used
- ◆ For this analysis, new generators with signed applications will try to buy full TEC from donors instead of waiting for access
 - ◆ Not considering overrun and other products
- ◆ Local works are based on local charging assumptions (up to a “MITS substation”)

Assumptions 2

- ◆ Cost of constraints due to increased utilisation estimated using historical cost (2006 and 2007)
- ◆ Generation scaled (across GB) to meet demand condition
- ◆ Trading occurs at every opportunity and donors are willing to sell when they themselves are not generating


Steps to estimate cost of constraint Generator utilisation component

- ◆ Step 1: Obtain average seasonal load factors for all plant types (2001/02 to 2007/08)
- ◆ Step 2: Consider all existing and new signed generators in the zone
- ◆ Step 3: Maximum tradable TEC calculated (up to headroom for this analysis) [in MW]
 - ◆ TEC donors = $(1 - \text{Load Factors})$
 - ◆ TEC recipients = Load Factors (default load factors for new Gen types suggested)
 - ◆ Maximum tradable MWs is the lower of the two
- ◆ Step 4: Current MWh utilisation versus historical cost of constraint estimated


Steps to estimate cost of constraint – utilization

- ◆ Step 5: The utilisation point at which no cost of constraint is incurred is estimated
- ◆ Step 6: Percentage increase in MWh utilisation calculated
- ◆ Step 7: By linear extrapolation, the increase in cost of constraint calculated
- ◆ Step 8: Using utilisation analysis, a high and low scenario is estimated


Utilisation component results with offset (Z15 – Thames Estuary only)



Utilisation component with different shared TEC load factors




Tradeable MWs against cost of constraint



Locational component

- ◆ This comes into effect beyond the headroom – e.g. any trades above 400MW aggregate in Z15
- ◆ Further analysis to be carried out beyond headroom to estimate impact of locational constraint
 - ◆ Local constraints – local works according to local charging assumption used (could be permanent)
 - ◆ Locational component includes changes to historical load factor behaviours, TEC donors selling at times when they would normally operate
 - ◆ Trades can be good or bad
 - ◆ Asymmetrical as we secure against multiple contingencies, i.e trade from A to B not symmetrical with B to A, therefore tends to cause more constraint cost
 - ◆ Ratio of load factors of recipient to donor TEC important – could cause reduction in cost of constraints if most frequent trades good

Utilisation and locational component results (Z15 – Thames Estuary only)



Results Summary

- ◆ Utilisation component

- ◆ Up to headroom, the additional cost of constraint in the Thames estuary is £0.3m per annum
- ◆ Utilisation more dominant in a zone like Z15 where the donor is mainly Grain oil and the recipients are both at Grain – no locational element
- ◆ Initial feel is that the cost of constraints will be in this order of magnitude but further work on other zones needed
- ◆ Low wind load factors mean a smaller increase in utilisation but increased volatility of wind could make it difficult to identify opportunities to schedule outages

- ◆ Locational component

- ◆ Minimal effect up to headroom, further analysis beyond headroom

Cost of Constraints - Refinements

- ◆ Ex post historical data used (i.e. following operator action)
 - ◆ Utilisation numbers used are already constrained numbers
 - ◆ Cost of constraint reduced
- ◆ Cost of replacement energy increasing
- ◆ Better estimates of load factors/behaviours of new generators by plant type – wind, interconnectors
- ◆ Upper and lower limits of cost of constraint estimation
 - ◆ High and low ranges
- ◆ Quarterly (seasonal) analysis might be more accurate but outage periods becoming longer and longer
- ◆ Interactivity between various zones
 - ◆ Utilisation increase in one zone leads to reductions in another – difficult so zonal analysis provides some sort of upper range
 - ◆ Shifting of system issues as the background changes due to trades might have to be explored

Next Steps

- ◆ Expand this work to other zones (including Scotland) to obtain full impact
- ◆ Further refinement of techniques to obtain better accuracy