

Appendix A – Proposed Grid Code Changes

Glossary and Definitions Changes

GLOSSARY AND DEFINITIONS

Amend the existing definitions of ‘System to Generator Operational Intertripping’ and ‘System to Generator Operational Intertripping Scheme’ as follows:

System to Generator Operational Intertripping A **Balancing Service** involving the initiation by a **System to Generator Operational Intertripping Scheme** of automatic tripping of the ~~User’s~~ circuit breaker(s) resulting in the tripping of **BM Unit(s)** or (where relevant) **Generating Unit(s)** comprised in a **BM Unit** to prevent abnormal system conditions occurring, such as over voltage, overload, **System** instability, etc, after the tripping of other circuit-breakers following power **System** fault(s).

System to Generator Operational Intertripping Scheme A **System to Generating Unit** or **System to CCGT Module Intertripping Scheme** forming a condition of connection and specified in Appendix F3 of the relevant **Bilateral Agreement**, being either a **Category 1 Intertripping Scheme**, **Category 2 Intertripping Scheme**, **Category 3 Intertripping Scheme**, ~~or Category 4 Intertripping Scheme~~ or **Category 5 Intertripping Scheme**.

Insert the following new definitions:

Category 5 Intertripping Scheme A **System to Generator Operational Intertripping Scheme** which :-
(i) is required to alleviate on overload on a circuit or number of circuits that form part of a **Derogated Non-Compliant Transmission Boundary**; and
(ii) **can only be armed in respect of a Derogated Non-Compliant Transmission Boundary**.

Derogated Non-Compliant Transmission Boundary **Transmission** circuit(s) forming part of the **GB Transmission System** which is the subject of a **GB SQSS Derogation**.

GB SQSS Derogation A direction issued to **NGET** by the **Authority** relieving **NGET** from obligations under the **Security and Quality of Supply Standard**.