

# Exercise Neptune Findings

---

Overview

# Exercise Neptune Findings

Firm Load Shedding of Above 25,000 tpa Sites Across Previous Exercises

Contact Type	Krakatoa 2003		Load Shed 2004		Moscow 2005		Neptune 2006	
	No.	%	No.	%	No.	%	No.	%
Successful (could turn off)	1780	47%	1214	31%	582	36%	1112	43%
Could not turn off	705	19%	606	16%	515	32%	612	24%
Total sites where contact was made	2485	65%	1820	47%	1097	68%	1724	66%
Contact details incorrect	1318	35%	2063	53%	512	32%	878	34%
Total attempted contacts	3803		3883		1609		2602	

- ◆ Performance of shipper emergency interruption remains variable.
- ◆ Firm load shedding of DN load showed a slight decrease in sites that could be contacted but an increase in sites who could turn off gas.
- ◆ HSE will publish the Neptune report on their web site with organisation names