

## BMU Capability and Price Submission Report

This report constitutes the publication of Holding Payment rates and other information as required by Clause 4.1.3.13A of the Connection and Use of System Code. The contents of the report include

- i. the available Response volume in respect of each applicable User's BM Unit(s) as indicated by :
  - Maximum Primary Response at 0.2Hz, 0.5Hz, 0.8Hz deviation from System nominal frequency of 50Hz
  - The amount of de-load from MEL required to deliver the maximum Primary Response at 0.2Hz, 0.5Hz, 0.8Hz deviation from System nominal frequency of 50Hz
  - Maximum Secondary Response at 0.2/0.2Hz, 0.5/0.5Hz deviation from System nominal frequency of 50Hz ( NB : 0.2/0.2 Hz means the point on the Frequency Response matrix corresponding to 0.2Hz deviation under Primary Response and 0.2Hz deviation under Secondary Response).
  - The amount of de-load from MEL required to deliver the maximum Secondary Response at 0.2/0.2Hz, 0.5/0.5Hz deviation from System nominal frequency of 50Hz
  - Maximum High Frequency Response at 0.2Hz, 0.5Hz deviation from System nominal frequency of 50Hz
  - The amount of de-load from MEL required to deliver the maximum High Frequency Response at 0.2Hz, 0.5Hz deviation from System nominal frequency of 50Hz; and
- ii. The holding rates for Primary, Secondary and High Mandatory Frequency Response in respect of each applicable User's BM Unit(s) to apply in December 2005.

MW Response Capability by BMU

UNIT	Mode	Primary Response (Max. MVAhns)				Secondary Response (Max. MVAhns)				High Frequency Response (Max)					
		0.2Hz	0.5Hz	0.8Hz	1.2Hz	0.2/0.2Hz	0.5/0.5Hz	0.8/0.8Hz	1.2/1.2Hz	0.2Hz	0.5Hz	0.8Hz	1.2Hz		
ABTH7	A	40	250	72	250	72	250	48	250	120	250	38	185	55	185
ABTH8	A	40	250	72	250	72	250	48	250	120	250	38	185	55	185
ABTH9	A	40	250	72	250	72	250	48	250	120	250	38	185	55	185
BASE-1	A	21	235	52	235	80	235	33	235	80	235	22	235	52	235
BASE-2	A	3	17	8	17	12	17	9	17	9	17	2	17	5	17
BARKB-2	A	30	215	63	215	72	215	36	215	87	215	33	69	69	23
BARK1	A	20	145	42	145	48	145	24	145	58	145	22	46	46	15
BRGG-1	A	16	144	32	144	0	144	16	144	40	144	14	96	34	96
BRV1-1	A	15	62	25	62	31	62	22	62	37	62	10	62	27	47
CDCL-1	A	30	160	40	160	40	160	34	160	40	160	27	120	40	120
CLAC1	A	3	37	6	37	6	37	3	37	8	37	3	30	6	30
CNOPS-1	A	22	126	51	126	70	126	28	126	70	126	20	100	45	100
CNOPS-2	A	22	126	51	126	70	126	28	126	70	126	20	100	45	100
CNOPS-3	A	22	126	51	126	70	126	28	126	70	126	20	100	45	100
CNOPS-4	A	22	126	51	126	70	126	28	126	70	126	20	100	45	100
COCK-1	A	15	168	42	168	48	168	10	168	25	168	6	138	7	138
COCK-2	A	15	168	42	168	48	168	10	168	25	168	6	138	7	138
COCK-3	A	15	168	42	168	48	168	10	168	25	168	6	138	7	138
COCK-4	A	15	168	42	168	48	168	10	168	25	168	6	138	7	138
CORR-1	A	18	80	34	80	40	80	22	80	39	80	22	24	40	0
COSO-1	A	24	323	44	323	48	323	48	323	110	323	28	258	42	258
COTPS-1	A	29	277	50	277	62	277	35	277	60	277	30	122	60	122
COTPS-2	A	29	277	50	277	62	277	35	277	60	277	30	122	60	122
COTPS-3	A	29	277	50	277	62	277	35	277	60	277	30	122	60	122
COTPS-4	A	29	277	50	277	62	277	35	277	60	277	30	122	60	122
CRUA-1	A	10	110	25	110	37	110	12	110	30	110	10	84	25	48
CRUA-2	A	10	110	25	110	37	110	12	110	30	110	10	84	25	48
CRUA-3	A	7	30	15	30	21	30	9	30	24	30	5	25	13	15
CRUA-4	A	7	30	15	30	21	30	9	30	24	30	5	25	13	15
DRAC1	A	136	350	158	350	158	350	158	350	158	350	60	293	100	293
DEEP-1	A	20	180	60	180	86	180	22	180	80	180	24	96	52	96
DERW-1	A	13	90	35	90	45	90	16	90	40	90	16	90	32	72
DIDCBS	A	86	260	84	260	84	260	60	260	136	260	40	220	100	160
DIDCB-1	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-2	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-3	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-4	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-5	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-6	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-7	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-8	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-9	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-10	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-11	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-12	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-13	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-14	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-15	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-16	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-17	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-18	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-19	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-20	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-21	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-22	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-23	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-24	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-25	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-26	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-27	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-28	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-29	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-30	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-31	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-32	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-33	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-34	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-35	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-36	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-37	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-38	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-39	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-40	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-41	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-42	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-43	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-44	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-45	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-46	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-47	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-48	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-49	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-50	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-51	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-52	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-53	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-54	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-55	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-56	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-57	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-58	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-59	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-60	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-61	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-62	A	120	203	120	203	120	203	60	203	103	203	68	115	60	115
DIDCB-63	A	120	203	120	203	120	203	60	203	10					

Bmurname	Primary Price £/MW/h	Secondary £/MW/h	High Frequency £/MW/h
ABTH7	3.5	4	4
ABTH8	3.5	4	4
ABTH9	3.5	4	4
BAGE-1	2.52	2.92	0.75
BAGE-2	2.52	2.92	0.75
BARK-1	6.26	6.26	22.99
BARKB2	5	5	20
BRGG-1	50	50	50
BRYP-1	4	2	5
CDCL-1	3.8	1.9	15.2
CNQPS-1	3.8	1.9	13.3
CNQPS-2	3.8	1.9	13.3
CNQPS-3	3.8	1.9	13.3
CNQPS-4	3.8	1.9	13.3
COCK-1	5.9	5.9	1.22
COCK-2	5.9	5.9	1.22
COCK-3	5.9	5.9	1.22
COCK-4	5.9	5.9	1.22
CORB-1	7.6	1.9	9.5
COSO-1	4.31	4.31	3.01
COTPS-1	1.8	4	8.6
COTPS-2	1.8	4	8.6
COTPS-3	1.8	4	8.6
COTPS-4	1.8	4	8.6
CRUA-1	4.9	3.9	2
CRUA-2	4.9	3.9	2
CRUA-3	4.9	3.9	2
CRUA-4	4.9	3.9	2
DAMC-1	4.4	5.4	13
DEEP-1	3	2	13.9
DERW-1	5	5	15
DIDC1	5.5	1	4.5
DIDC2	5.5	1	4.5
DIDC3	5.5	1	4.5
DIDC4	5.5	1	4.5
DIDCB5	300	0	300
DIDCB6	8	0	8
DINO-1	4.9	3	9
DINO-2	4.9	3	9
DINO-3	4.9	3	9
DINO-4	4.9	3	9
DINO-5	4.9	3	9
DINO-6	4.9	3	9
DRAXX-1	0	1	18
DRAXX-2	0	1	18
DRAXX-3	0	1	18
DRAXX-4	0	1	18
DRAXX-5	0	1	18
DRAXX-6	0	1	18
EECL-1	2.85	0.95	15.2
EGGPS-1	4	4	9
EGGPS-2	4	4	9
EGGPS-3	4	4	9
EGGPS-4	4	4	9
ERRO-1	100	100	100
ERRO-2	100	100	100
ERRO-3	100	100	100
FASN-1	200	200	200
FASN-2	200	200	200
FASN-3	200	200	200
FAWL1	3.2	4.09	0.65
FAWL3	3.2	4.09	0.65
FAWN-1	5.68	0.58	1.37
FELL-1	1.9	1.9	0.44
FERR-1	5	4	10.5
FERR-2	5	4	10.5
FERR-3	5	4	13
FERR-4	5	4	13

FFES-1	4.9	3	9
FFES-2	4.9	3	9
FFES-3	4.9	3	9
FFES-4	4.9	3	9
FIDL-1	5	4	10.5
FIDL-2	5	4	10.5
FIDL-3	5	4	16
FIDL-4	5	4	16
FINL-1	50	50	50
FOYE-1	10	10	30
FOYE-2	10	10	30
GRAI-1	4.85	0.97	14.55
GRAI-3	4.85	0.97	14.55
GRAI-4	4.85	0.97	14.55
GRMO-1	100	100	100
GYAR-1	1	0	10.5
HUMR-1	150	150	150
INDQ-1	165	165	165
IRNPS-1	1.46	1.46	15.04
IRNPS-2	1.46	1.46	15.04
KEAD-1	5	4	10.5
KILLPG-1	2.85	1.52	14.25
KILLPG-2	2.85	1.52	14.25
KILNS-1	15.68	10.26	5.4
KINO-1	3.4	1.94	8.73
KINO-2	3.4	1.94	8.73
KINO-3	3.4	1.94	8.73
KINO-4	3.4	1.94	8.73
KLYN-A-1	9,999.00	9,999.00	9,999.00
LBAR-1	6.5	0	5.5
LITTD1	3.97	5.89	1.71
LITTD2	3.97	5.89	1.71
LITTD3	3.97	5.89	1.71
LOAN-1	5.71	5	1.22
LOAN-2	5.71	5	1.22
LOAN-3	5.71	5	1.22
LOAN-4	5.71	5	1.22
MEDP-1	5	4	12.5
NANT-1	75	75	75
PEHE-1	3	2	9
PEHE-2	4	2	9
PETEM1	4.5	2	7
RATS-1	4.85	1.94	9.7
RATS-2	4.85	1.94	9.7
RATS-3	4.85	1.94	9.7
RATS-4	4.85	1.94	9.7
ROCK-1	4.31	4.31	3.01
ROOS-1	22	14.4	12
RUGPS-6	3	2	9.5
RUGPS-7	3	2	9.5
RYHPS-1	4.4	5.4	13
SCCL-1	3	4	19.9
SCCL-2	3	4	17.9
SCCL-3	3	4	24.9
SEAB-1	6	6	20
SEAB-2	6	6	20
SHBA-1	5.5	2	12
SHBA-2	5	2	9
SHOS-1	4.4	5.4	13
SHOT-1	2	3	11.5
SIZB-1	25.63	43.18	42.65
SIZB-2	25.63	43.18	42.65
SLOY-1	100	100	100
SLOY-2	100	100	100
SLOY-3	100	100	100
SLOY-4	100	100	100
SPLN-1	14.99	14.99	14.99
SUTB-1	1.8	4	12.75
TESI-1	9,999.00	9,999.00	9,999.00

TESI-2	9,999.00	9,999.00	9,999.00
TILB10	2.66	3.55	4
TILB-7	2.66	3.55	4
TILB-8	2.66	3.55	4
TILB-9	2.66	3.55	4
USKM-13	2.21	1.94	0.59
USKM-14	2.21	1.94	0.59
USKM-15	2.21	1.94	0.59
WBUPS-1	1.8	4	10.5
WBUPS-2	1.8	4	10.5
WBUPS-3	1.8	4	10.5
WBUPS-4	1.8	4	10.5