

**VERSION FOR INDUSTRY  
CONSULTATION**

Responses should be sent to  
shafiq.ullah@uk.ngrid.com  
on or before 11<sup>th</sup> July 2006

## **PROPOSED AMENDMENT REPORT**

### **STC Proposed Amendment CA021**

#### **Exchange of Certain Investment Planning Data**

*The purpose of this report is to assist the Authority  
in their decision of whether to implement  
Amendment Proposal CA021*

Amendment Ref	CA021
Issue	1.0
Date of Issue	27 <sup>th</sup> June 2006
Prepared by	STC Committee

**I DOCUMENT CONTROL****a STC Document Control**

<b>Version</b>	<b>Date</b>	<b>Author</b>	<b>Change Reference</b>
0.1	26/05/06	STC Committee	Draft for STC Committee
0.2	05/06/06	STC Committee	Revised draft for STC Committee
0.3	16/06/06	STC Committee	Third draft for STC Committee
1.0	27/06/06	STC Committee	Draft for Industry Consultation

**b Document Location**

National Grid Website:

<http://www.nationalgrid.com/uk/Electricity/Codes/sotocode/>

**c Distribution**

<b>Name</b>	<b>Organisation</b>
The Gas and Electricity Markets Authority	Ofgem
STC Parties	Various
Interested Parties	Various
Core Industry Document Owners	Various
National Grid Industry Information Website	

**II CONTENTS TABLE**

<b>I</b>	<b>DOCUMENT CONTROL.....</b>	<b>2</b>
	a STC Document Control .....	2
	b Document Location .....	2
	c Distribution .....	2
<b>II</b>	<b>CONTENTS TABLE.....</b>	<b>3</b>
<b>1.0</b>	<b>SUMMARY AND RECOMMENDATION.....</b>	<b>4</b>
<b>2.0</b>	<b>PURPOSE AND INTRODUCTION .....</b>	<b>4</b>
<b>3.0</b>	<b>THE PROPOSED AMENDMENT .....</b>	<b>5</b>
<b>4.0</b>	<b>ALTERNATIVE AMENDMENTS .....</b>	<b>7</b>
<b>5.0</b>	<b>EVALUATION PHASE.....</b>	<b>7</b>
<b>6.0</b>	<b>STC PARTIES' ASSESSMENTS .....</b>	<b>13</b>
<b>7.0</b>	<b>IMPACT ON THE STC.....</b>	<b>14</b>
<b>8.0</b>	<b>IMPACT ON CORE INDUSTRY DOCUMENTS .....</b>	<b>15</b>
<b>9.0</b>	<b>STC COMMITTEE VIEWS AND RECOMMENDATION .....</b>	<b>15</b>
<b>10.0</b>	<b>IMPLEMENTATION AND TIMESCALES .....</b>	<b>16</b>
<b>11.0</b>	<b>INDUSTRY VIEWS AND REPRESENTATIONS .....</b>	<b>16</b>
	<b>ANNEX 1 - AMENDMENT PROPOSAL FORM .....</b>	<b>17</b>
	<b>ANNEX 2 - PROPOSED TEXT TO AMEND THE STC .....</b>	<b>19</b>
	<b>ANNEX 3 - JPC EVALUATION .....</b>	<b>23</b>
	<b>ANNEX 4 - JPC EVALUATION FURTHER INFORMATION .....</b>	<b>42</b>
	<b>ANNEX 5 - COPIES OF COMMENTS RECEIVED ON THE PROPOSED AMENDMENT REPORT .....</b>	<b>45</b>

## **1.0 SUMMARY AND RECOMMENDATION**

- 1.1 STC Amendment Proposal CA021 seeks to amend Schedule 3 of the STC to allow STC Parties to disclose specific data to Transmission Owners on an enduring basis for the purposes of transmission investment planning, specifically stability studies.
- 1.2 Amendment Proposal CA021 was proposed by National Grid Electricity Transmission plc (“National Grid”) and submitted for consideration to the STC Committee Meeting on Tuesday, 18<sup>th</sup> April 2006. The Committee recommended that it proceed to the Evaluation Phase.
- 1.3 Under this Evaluation Phase, the Committee commissioned a working group, which met once by teleconference. The working group reported back to the STC Committee Meeting on Wednesday 17<sup>th</sup> May 2006. The Committee then recommended that CA021 proceed to the Assessment and Report Phase.

### **STC Committee Provisional Recommendation**

- 1.4 The STC Committee provisionally recommends that CA021 be approved for implementation.
- 1.5 Should the Authority approve CA021, the STC Committee provisionally recommends that the STC be modified 5 business days after the Authority’s decision.

## **2.0 PURPOSE AND INTRODUCTION**

- 2.1 This Amendment Report has been prepared and issued by the STC Committee under the rules and procedures specified in the System Operator – Transmission Owner Code. It addresses issues relating to the exchange of data for transmission investment planning.
- 2.2 Further to the submission of Amendment Proposal CA021 (see Annex 1), this document is addressed and furnished to persons who have a relevant interest in the Proposed Amendments and invites views upon Amendment Proposal CA021.
- 2.3 This document outlines the nature of the STC changes that are proposed. It incorporates the STC Committee’s provisional recommendation concerning the Amendment.
- 2.4 This Proposed Amendment Report has been prepared in accordance with the terms of the STC. An electronic copy can be found on the National Grid website, at <http://www.nationalgrid.com/uk/Electricity/Codes/sotocode/>.

### 3.0 THE PROPOSED AMENDMENT

- 3.1 Schedule 3 of the STC sets out the information and data permitted to be disclosed by a STC Party to a Transmission Owner in accordance with Section F of the STC. During the drafting of the STC, Ofgem imposed a 'time limit' on some of the STC provisions which allow Investment Planning Data to be provided by National Grid to a Transmission Owner. The existing provisions of paragraph 2.4.3 of Schedule 3, which permit National Grid to provide certain data to Transmission Owners relating to Generation Units outside of their Boundary of Influence, and which is particularly used for stability studies, have been hard coded to become obsolete on 30<sup>th</sup> September 2006. Ofgem expected National Grid and Transmission Owners to liaise prior to the expiration of the existing provisions in order to develop a more enduring set of arrangements in this area, and it is the introduction of these enduring arrangements that is proposed by CA021.
- 3.2 Under the current BETTA structure, Transmission Owners are responsible for undertaking transmission investment planning for their systems, and it was recognised by Ofgem that, in order for Transmission Owners to discharge their relevant licence obligations in this area, some exchange of investment planning data would need to take place. However, in addition to promoting efficiency in the discharge of the licence obligations of licensees, one of the objectives of the STC is the facilitation of effective competition in generation and supply. Ofgem believed "that, from time to time, there may be a tension between these priorities", and that "this tension is particularly evident in relation to information exchange between the GB System Operator [National Grid] and Transmission Owners with associated generation and supply activities".<sup>1</sup> The STC Committee notes that a more accurate reference would have been to Transmission Owners with affiliates who have such interests.
- 3.3 Ofgem accepted that the relevant information within Transmission Owners' Boundaries of Influence would be needed on an enduring basis, but had not originally envisaged that data from outside of the Boundary of Influence would be required. However, the Transmission Licensees indicated to Ofgem that, in order for Transmission Owners to be able to carry out stability studies, such an exchange of data would be necessary. Therefore, and in light of the fact that:
- a) the consequences would essentially only be to expand the geographic scope of the information that it was envisaged that Transmission Owners would in any event have available in relation to their own transmission systems rather than the nature of the information itself; and
  - b) any information provided to Transmission Owners would remain the subject of Special Condition C of their Transmission Licences (which limits the disclosure of any information that they do receive under the STC),

Ofgem stated in its March 2005 consultation document that it was of the view that it would be appropriate to make provision in Schedule 3 to permit the exchange of this data, albeit on a time limited basis.<sup>2</sup> This was confirmed in Ofgem's March 2005 conclusions document, which also fixed the time limit as 30<sup>th</sup> September 2006.<sup>3</sup>

---

<sup>1</sup> Information Exchange under the STC – Ofgem conclusions (March 2005), paragraph 3.14

<sup>2</sup> Information Exchange under the STC – An Ofgem consultation (March 2005), paragraph 2.14

<sup>3</sup> Information Exchange under the STC – Ofgem conclusions (March 2005), paragraph 3.15

- 3.4 Ofgem also stated however, that, in the interim, it would be appropriate for Transmission Licensees to review these arrangements. In particular, Ofgem suggested that the Licensees should consider further whether it may be more appropriate for National Grid to carry out system stability studies and/or whether the network model made available to Transmission Owners should, in relation to some parts of the system, be an equivalent model.
- 3.5 The STC Committee therefore asked the Joint Planning Committee (JPC) on behalf of the Transmission Licensees to review the arrangements. A summary of these considerations, including an assessment of the potential options, is included in Section 5 of this document, and the full report from the JPC is attached as Annex 3.
- 3.6 The conclusion of the Transmission Licensees was that the preferred approach would be for Transmission Owners to continue to carry out stability studies, but that paragraph 2.4.3 of Schedule 3 of the STC be amended to specifically target the minimum data required for Transmission Owners to be able to undertake such stability studies, and it is this that is proposed by CA021.
- 3.7 The following revisions are therefore proposed:
- a) To restrict the exchange of information and data to that which is specifically required for stability studies, rather than allowing National Grid to disclose to Transmission Owners all data items listed in Appendix A to the Planning Code and in OC2.4.2.1(a) as at present. This will be done through permitting the exchange only of information listed in Schedule 1 of the Data Registration Code less a number of data items not required as specified in a new Schedule 14 of the STC. This will therefore effectively take out reference to any demand, user data and generator data that is not required specifically for stability studies.
  - b) To provide lists (in no particular order), rather than ranking orders, of generation units which National Grid forecasts to be synchronised to meet specified levels of demand in the current and following six financial years. These demand levels will include, but not be limited to, the minimum demand, 60% of peak demand and peak demand on the GB Transmission System.
  - c) Add the exchange of Investment Planning network data in the current and following six financial years that will materially affect the planning or development of the receiving Transmission Owner's Transmission System. This would therefore include any changes which would alter the parameters of the network (i.e. are not like for like asset replacement), and which may be inside or outside of the Boundary of Influence.
- 3.8 These proposals would therefore result in significant changes to paragraph 2.4.3 of Schedule 3, including the removal of the reference to 30<sup>th</sup> September 2006 and a restructuring of the paragraph to be consistent with the structure of paragraph 2.4.2.
- 3.9 Minor changes to paragraph 2.4.2 are also proposed to correct the numbering of some sub-paragraphs and to streamline the drafting of paragraph 2.4.2(b).
- 3.10 The final proposed legal text to give effect to Amendment Proposal CA021 is attached as Annex 2 of this document.

## **4.0 ALTERNATIVE AMENDMENTS**

- 4.1 No Alternative Amendments to CA021 have been submitted.

## **5.0 EVALUATION PHASE**

- 5.1 The STC Committee considered that CA021 should be referred to the Evaluation Phase, and therefore commissioned a working group to review and develop the legal text for the proposal. The working group met once by teleconference on 8<sup>th</sup> May 2006, and a change to the structure of the proposed Schedule 14 was agreed.

- 5.2 However, prior to the submission of CA021 to the Committee, the amendment proposal had been extensively evaluated on behalf of the Transmission Licensees by the Joint Planning Committee (JPC). This evaluation is summarised below, and first considers the relevant obligations on the Transmission Owners, and the situation prior to BETTA, before assessing four potential approaches to developing paragraph 2.4.3 of Schedule 3 of the STC in response to the expiration of the existing time limit.

### **Obligations on the Transmission Owners**

- 5.3 Transmission Owners have various obligations to fulfil, including:
- a) Under the Electricity Act 1989, holders of a transmission licence have a duty to develop and maintain an efficient, co-ordinated and economical system of electricity transmission.
  - b) Each company's Transmission Licence further requires them to plan and develop their transmission systems in accordance with the GB Security and Quality of Supply Standards (GBSQSS) and STC.
  - c) The GBSQSS (under paragraph 4.8) requires the transmission system to be planned such that there shall not be system instability for conditions on the GB transmission system which ought to be reasonably expected to arise in the course of a year of operation.
  - d) In accordance with the STC each Transmission Owner shall develop and maintain a transmission investment plan in respect of the current and each of the following six financial years.
- 5.4 To undertake a stability study the following information is required for the entire system under consideration:
- a) Network topology and connectivity including branch parameters;
  - b) Reactive compensation system parameters and relevant control system details;
  - c) Demand;
  - d) Generation – connectivity, location and type;
  - e) Generator dynamic parameters; and

- f) Details of relevant generator control systems.
- 5.5 Therefore, in order to meet its obligations to plan its own system in accordance with the GBSQSS, and assess system stability, each licensee requires information on conditions on the GB transmission system which ought to be reasonably expected to arise in the course of a year of operation, including:
- a) The system data described above in line with each transmission company's seven year investment plan. For stability studies each company will need an accurate representation of the whole GB network.
  - b) Generation and demand patterns for a variety of demand conditions. A list of generators that would be running to meet each level of demand would be required, although a specific ranking order of these generators would not be necessary.

### **Stability Analysis pre-BETTA**

- 5.6 Before the introduction of BETTA, the Scottish Transmission Licensees had to comply with their individual licence standards and the Scottish Grid Code. Joint system stability studies were carried out under the British Grid Systems Agreement (BGSA), between the three GB Transmission Licensees.
- 5.7 Each year, benchmark thermal, voltage and transient stability studies were undertaken at various demand levels and over a number of years. These co-ordinated studies involved the exchange of transmission data for the whole GB system, and this co-ordinated approach allowed verification of data and permitted the Licensees to investigate the cause of any differences in the study results. Through this process it became evident that modelling the whole GB system was important to the outcome of transient stability studies. One example was the representation of the Static Var Compensators (SVCs) in the south of England, which proved to have a significant impact on the stability of generators in Scotland for critical flows on the then Anglo-Scottish Interconnector.
- 5.8 Confidentiality of data was dealt with under various sections of the Transmission Licences, Public Electricity Supply Licences, Grid Codes, Distribution Codes and the BGSA itself. The BGSA had an extensive clause defining how the Transmission Licensees could use any information or data supplied to and acquired from the other parties in performing the permitted activities. This allowed for the exchange of complete network, demand and generation data and the use of the information was covered under a confidentiality agreement.

### **Potential Options Assessed**

- 5.9 Four approaches (Options a - d) to developing paragraph 2.4.3 of Schedule 3 of the STC with regards to the expiration of the existing time limit were considered, and these are discussed in detail below.

#### Option a – Do nothing (i.e. let the clause lapse)

- 5.10 If the clause were to lapse, then National Grid would no longer be able to pass the specified data to the Scottish Transmission Owners. If this data were not transferred, then the Transmission Owners would not be able to fulfil their licence obligations to carry out stability studies, and would need to be relieved of their obligations to carry out stability studies under the GBSQSS.

This would require a change to the Scottish Transmission Owners' Transmission Licences.

- 5.11 Further, if stability studies were not completed at all as part of the Investment Planning process, then any stability problems would have to be addressed in operational timescales, which has potentially severe constraint cost implications. For example, in an extreme case, a new generator may have to be permanently constrained off due to stability concerns. The impact of this would be more severe if there was a shortage of generation in the future, putting the system under even greater stress.
- 5.12 An alternative approach to this would be for National Grid to carry out stability studies and plan appropriate investments for the whole of Great Britain. This would, however, undermine the prime obligation of the Transmission Owners to ensure compliance with GBSQSS and plan and develop their system in an efficient, co-ordinated and economical manner. For example, investment solutions often cover several non-compliance issues, and investments may therefore no longer be co-ordinated if different companies had responsibility for different aspects of compliance (e.g. an SVC can address both voltage and stability issues).
- 5.13 Therefore, it was concluded that letting paragraph 2.4.3 lapse would not be an acceptable option, because the Scottish Transmission Licensees would not be able to meet their license conditions.

#### Option b – Use of dynamic equivalents

- 5.14 It has been previously suggested by Ofgem that the network model made available to Transmission Owners could, in relation to some parts of the GB transmission system, be an equivalence model. However, compared to carrying out a detailed stability study on a full network, the use of equivalents has the following disadvantages and problems:
- a) Dynamic equivalents are less accurate because of the very large number of non-linear variables involved (leading to potential over or under investment).
  - b) With equivalents, it is difficult to determine the exact nature and cause of an instability condition and therefore potential reinforcement solutions may be ill judged. Such an approach could lead to either over or under investment.
  - c) The use of equivalents assumes that there are only network solutions to stability problems, whereas in reality these could be rectified using alternative control system solutions employed on generating plant, which may provide a cheaper solution.
  - d) An equivalent is specific to one single scenario and does not allow for sensitivity analysis related to variations in the generation and demand pattern.
  - e) The skills required to produce equivalents are specialised and the process is very resource intensive. Equivalents would need to be set up to cover a wide range of scenarios and these would each need to be fully validated against a wide range of desired stability studies.
- 5.15 In summary, it was therefore concluded that the use of dynamic equivalents carries a high risk of inefficient (or even non-compliant) network investments,

planned by using system models in which the Transmission Owners would have reduced confidence. Therefore, it was considered that the use of dynamic equivalents would not represent an acceptable alternative.

#### Option c – Use of SYS networks instead of Investment Planning networks

- 5.16 As currently written, STCP 22-1 assumes the creation of hybrid networks for all Investment Planning studies other than summer minimum. These hybrid networks to be used for such other studies are created by joining an Investment Planning network to a Seven Year Statement (SYS) network outside the Boundary of Influence.
- 5.17 Generally, a Transmission Owner's Investment Planning network differs considerably from the SYS networks for the next seven years. For example, SYS networks may contain reinforcements that have an impact on stability, but would not be contained in an Investment Planning network. A specific example of this is the fourth England-Scotland interconnector circuit, which has a significant impact on stability. This reinforcement would be included in a SYS dataset but not an Investment Planning network. In particular, there is considerable risk that non-optimal solutions to stability problems could be proposed or that potential stability issues are not assessed and corrected adequately.
- 5.18 Previous studies to determine the Anglo-Scottish Interconnector capacity, carried out under the BGSA, did use SYS networks. However, it should be noted that pre-BETTA the Interconnector capability was governed under a contractual/commercial relationship between the three Transmission Licensees rather than a requirement to satisfy the GBSQSS as now. The purpose of past benchmarking studies was not therefore to identify necessary investments based on GB power flows, rather it was to monitor known stability, voltage and thermal limits for the system over the next year or two to ensure no erosion of Interconnector capability was likely to occur due to developments in each Licensee's area. For this purpose it was adequate to study the Interconnector capability a couple of years out using the SYS networks where there was little divergence between the SYS networks and the Investment Planning view. However, it was recognised that the SYS networks would not be adequate for the full planning cycle due to the increasing divergence that would result from differing investments over the later years of the cycle.
- 5.19 It should also be noted that, although STCP 22-1 currently assumes the use of Investment Planning networks, without the use of hybrids, for the study of the summer minimum condition, this is not workable under the current drafting of Schedule 3. Paragraph 2.4.3 does allow for the exchange of User data at summer minimum for the purposes of undertaking stability studies, but contains no provisions relating to the exchange of Investment Planning networks. This has therefore significantly compromised the ability of the Transmission Owners to undertake stability studies, and is clearly an issue that would have needed to have been resolved even without the time limit on User data in paragraph 2.4.3.
- 5.20 Finally, and in any event, the current processes for the exchange of SYS networks do not allow for the inclusion of generator dynamic data or any control system models, so these networks would not be adequate for stability studies.

- 5.21 In summary, it was concluded that the use of SYS networks for stability studies in planning timescales would not be considered an acceptable alternative.

Option d – Revise paragraph 2.4.3 to include only the specific information and data needed for stability studies

- 5.22 The final approach considered was to amend paragraph 2.4.3 of Schedule 3 to remove the time limit and to specifically target the minimum data required for the Transmission Owners to be able to undertake stability studies. Under this scenario, the following revisions would be proposed:

- a) To restrict the exchange of information and data to that which is specifically required for stability studies, rather than allowing National Grid to disclose to Transmission Owners all data items listed in Appendix A to the Planning Code and in OC2.4.2.1(a) as at present. This would be done through permitting the exchange only of information listed in a new Schedule 14 of the STC. This would be based on Schedule 1 of the Data Registration Code (DRC) less any demand, user data and generator data that is not required specifically for stability studies. The advantage of this approach is therefore that the exchange of many of the potentially commercially sensitive data items would no longer be permitted.
- b) To provide lists (in no particular order), rather than ranking orders, of generation units which National Grid forecasts to be synchronised to meet specified levels of demand in the current and following six financial years. These demand levels will include, but not be limited to, the minimum demand, 60% of peak demand and peak demand on the GB Transmission System.
- c) Add the exchange of Investment Planning network data in the current and following six financial years that will materially affect the planning or development of the receiving Transmission Owner's Transmission System. This would therefore include any changes which would alter the parameters of the network (i.e. are not like for like asset replacement), and which may be inside or outside of the Boundary of Influence.

- 5.23 This approach would minimise the amount of User data to be exchanged, but would represent an increase in the number of demand levels that would be assessed, compared to just the Summer Minimum as under the current provisions. These numerous scenarios are considered necessary because:

- a) Traditionally, the GB power system stability problem has been considered to be most onerous under minimum system demand conditions when fewer machines are running and the overall synchronising power is lower. Importantly, due to the higher network voltage profile seen under this condition, those machines that are running may be close to unity power factor or operating in the leading mode resulting in a lower stability margin.
- b) However, past experience has indicated the worst case for stability on the Anglo-Scottish Interconnector occurred at approximately 60% demand.
- c) Additionally, dynamic stability and transient stability are traditionally issues for synchronous generators whereas voltage stability becomes an increasing problem for wind farms due to their reliance on induction generator technology. In view of the growth of renewable generation, in

particular wind generation and subsequent significant changes in the disposition of generation, it would be considered prudent to look at a range of demand conditions, including peak.

- 5.24 This was considered to be the preferred approach in that it would allow all the Transmission Licensees to carry out detailed stability studies as required by their transmission licences. Further, the User information that would be exchanged would be significantly reduced, and would exclude most of the information that could be considered commercially sensitive.

### **JPC Recommendation**

- 5.25 The JPC therefore recommended to the STC Committee that paragraph 2.4.3 of Schedule 3 be amended to allow for the enduring exchange of certain demand, generator and investment planning data, as detailed in Option d above. The JPC provided a record of its considerations and recommendation in a report to the STC Committee, which is attached as Annex 3 of this document, and upon which the above paragraphs have been heavily based.

### **STC Working Group Evaluation**

- 5.26 Following the conclusion of the JPC's deliberations, National Grid proposed CA021 to give effect to the chosen solution. Although the solution itself had been fully evaluated by the JPC, the STC Committee concluded that further evaluation of the legal text proposed by National Grid and the Schedule proposed by the JPC would be beneficial.

- 5.27 The STC Committee therefore referred CA021 to the Evaluation Phase, and commissioned a working group, which met once by teleconference on 8<sup>th</sup> May 2006. The group identified two issues with the proposed implementation of the JPC's preferred approach:

- The proposed Schedule 14 comprised of data forming large parts of Schedule 1 of the Data Registration Code appeared to be a fairly unwieldy solution that would result in substantial duplication across the codes, also raising change control issues in that, if the Grid Code were to change, the STC would then also need to be amended; and
- Whether the intention was just to study GB wide peak and minimum demands, or whether it would also be necessary to study times of TO specific peak and minimum demands.

- 5.28 The working group therefore sought advice from the JPC on these matters, and, in response, the JPC suggested:

- A revised Schedule 14 [attached as Annex 4 of this document] including only the data from Schedule 1 of the Data Registration Code that would not be exchanged in the transmission planning process (on the basis that this would be shorter, and less liable to change); and
- That, with regards to studying GB wide or TO specific levels of demand, the flexibility provided by the originally proposed drafting was sufficient.

- 5.29 The working group therefore reported back to the STC Committee at its meeting on Wednesday 17<sup>th</sup> May 2006. The Committee agreed to change the structure of the proposed Schedule 14 of the STC to list the data from Schedule 1 of the Data Registration Code that should be excluded from the

data exchange, rather than included. This change has been reflected in the legal text contained in Annex 2 of this document.

5.30 The remainder of the legal text, having been reviewed by the working group, was approved by the Committee.

5.31 The Committee therefore agreed that CA021 was now ready to proceed to the Assessment and Report Phase.

## **6.0 STC PARTIES' ASSESSMENTS**

6.1 This section contains a summary of the analysis and impact assessment provided by STC Parties during the Assessment Phase in respect of the Proposed Amendments, in accordance with Section B, Paragraph 7.2.5.2 of the STC.

### **National Grid Assessment**

6.2 National Grid is supportive of Amendment Proposal CA021. National Grid has carried out an impact assessment on change proposal CA021 (Exchange of Certain Investment Planning Data).

6.3 The implementation of the proposed amendment will not require changes to any IS systems, nor will any additional works or monies be required to implement the proposed change.

6.4 However, National Grid believes that it is more relevant to consider the implications of the amendment not being made. National Grid notes the views of the JPC in evaluating the option of letting the provisions of paragraph 2.4.3 of Schedule 3 lapse (see paragraph 5.11). In such a situation it would not be possible for Scottish Transmission Owners to undertake stability studies, and there would therefore be a risk that connections to the transmission system would not be compliant with the planning and operating standards within the GBSQSS. Although permanently constraining off a new generator due to stability concerns would represent a very extreme case, National Grid agrees that, if non-compliance were to occur, and in the event that no derogations were granted, any stability problems may have to be addressed by National Grid as GB System Operator in operational timescales. This would potentially lead to increases in transmission constraints and hence balancing costs, a proportion of any such increase in which would be passed on to consumers. The impact of such non-compliance would be more severe if there was a shortage of generation in the future, putting the GB transmission system under even greater stress, and its integrity at risk.

6.5 The inability of Scottish Transmission Owners to undertake, and respond to, stability studies, could, in addition to jeopardising the integrity of the transmission system including National Grid's network in England & Wales, also lead National Grid to invest in reinforcements that would otherwise be sub-optimal.

### **Scottish Hydro-Electric Transmission Limited ("SHETL") Assessment**

6.6 SHETL is supportive of the Amendment Proposal CA021. SHETL has carried out an impact assessment on the change proposal CA021 (Exchange of Certain Investment Planning Data).

- 6.7 The implementation of the proposed amendment will not require changes to any IS systems, nor will any additional works or monies be required to implement the proposed change.
- 6.8 If nothing is done to clause 2.4.3 of the STC there will be huge risk for SHETL to ensure compliance with licence obligations and the GB SQSS. In particular SHETL would be unable to properly plan and develop its transmission system in accordance with the GBSQSS and also during planning its transmission system would it be unable to take into account the System Operator's obligations in regards to the stability of its own system in particular and the GB System in general. Furthermore this could also result in SHETL failing to make compliant offers (after considering impact assessment) for directly connected and embedded generations. This could lead to either over-investment or under-investment. As discussed in the Evaluation section of the paper, none of the other possible proposals would allow SHETL to properly and efficiently discharge its licence functions.

### **SP Transmission Ltd ("SPTL") Assessment**

- 6.9 SPTL is supportive of the Amendment Proposal CA021. SPTL has carried out an impact assessment on the change proposal CA021 (Exchange of Certain Investment Planning Data).
- 6.10 The implementation of the proposed amendment will not require changes to any IS systems, nor will any additional works or monies be required to implement the proposed change.
- 6.11 On the contrary, the failure to implement the proposed amendment would have a huge impact on SPTL. As a result of the existing sunset clause, the failure to implement the proposed amendment would mean that after the 30<sup>th</sup> September 2006 SPTL would be unable to properly comply with its Transmission Licence obligations. In particular it would be unable to properly plan and develop its transmission system in accordance with the GBSQSS, nor in planning its transmission system would it be properly able to take into account the System Operator's obligations under standard condition C17. In particular SPTL would be unable to properly take account of stability issues in planning its transmission system. This could lead to either over-investment or under-investment. As discussed in the Evaluation section of the paper, none of the other possible proposals would allow SPTL to properly and efficiently discharge its licence functions.

## **7.0 IMPACT ON THE STC**

- 7.1 The Proposed Amendment would require changes to paragraph 2.4.3 of Schedule 3 of the STC, the addition of a new Schedule 14 and the addition of one new definition in Section J. Minor changes to paragraph 2.4.2 of Schedule 3 are also proposed to correct the numbering of some sub-paragraphs and to streamline the drafting of paragraph 2.4.2(b).
- 7.2 The text required to give effect to the Proposed Amendment is contained as Annex 2 of this document.

## **8.0 IMPACT ON CORE INDUSTRY DOCUMENTS**

- 8.1 The Proposed Amendment would have no impact on Core Industry Documents or other industry documentation or require any changes to computer systems established under Core Industry Documents.

## **9.0 STC COMMITTEE VIEWS AND RECOMMENDATION**

- 9.1 The STC Committee believes that amendment of the STC on the basis of CA021 would better facilitate achievement of the applicable STC objectives, in particular applicable STC objective (b), in that the facilitation through the STC of an enduring process for the undertaking of stability studies would enable licensees to develop, maintain and operate an efficient, economical and coordinated system of electricity transmission.
- 9.2 The implementation of such provisions would also better facilitate achievement of applicable STC objective (a) as they would enable the efficient discharge by Scottish Transmission Owners of the obligations imposed upon them by their transmission licences and the Act, in particular the terms of Licence Condition D3, which requires them to plan and develop their transmission systems in accordance with the GBSQSS and the STC.
- 9.3 Indeed, were this Amendment Proposal not to be approved, Scottish Transmission Owners would be unable to fulfil this licence condition, and would need to be relieved of their obligations to carry out stability studies under the GBSQSS. Even if this implication was to be addressed, the STC Committee considers that the alternatives – not undertaking stability studies and addressing any stability problems in operational timescales, or National Grid undertaking stability studies for the whole of GB with the consequent resultant risk of uncoordinated and uneconomic investment – would be deficient when compared to the solution proposed by Amendment Proposal CA021.
- 9.4 Other potential approaches identified by the JPC included the use of equivalence models or SYS networks. However, the STC Committee agrees with the JPC's conclusions (described in paragraphs 5.14 – 5.21 of this report) that neither would represent acceptable alternatives. Indeed, in their Conclusions document that introduced the current time limit of 30<sup>th</sup> September 2006, Ofgem also noted that the use of equivalence models was highly problematic. In introducing this time limit, they expressed an expectation that the need to exchange this data should be reviewed but accepted "that the results of the review may be that the process put in place from go-live is the most appropriate process to follow on an enduring basis".<sup>4</sup>
- 9.5 As described in this report, the conclusion of this review as undertaken by the JPC was that, overall, the existing approach was the most appropriate, and, indeed, is the only process that is consistent with Transmission Owners' responsibilities for Investment Planning under the current BETTA structure. However, the JPC and the STC Committee, in developing CA021, have endeavoured both to minimise the exchange of data, by excluding most of that which could be considered commercially sensitive, and to resolve a number of other deficiencies in the current relevant provisions.
- 9.6 The STC Committee therefore recommends that the Authority should approve Amendment Proposal CA021 for implementation.

---

<sup>4</sup> Information Exchange under the STC – Ofgem conclusions (March 2005), paragraph 3.16

## **10.0 IMPLEMENTATION AND TIMESCALES**

- 10.1 Should the Authority approve Amendment Proposal CA021 it is recommended that the STC be modified 5 business days after the Authority's decision.

## **11.0 INDUSTRY VIEWS AND REPRESENTATIONS**

- 11.1 Views are invited from Industry parties upon the Proposed Amendment contained within this Proposed Amendment Report.

**Annex 1 - Amendment Proposal Form****STC Amendment Proposal Form****CA021**

<p><b>1. <u>Title of Amendment Proposal</u></b> Exchange of Certain Investment Planning Data</p>
<p><b>2. <u>Description of the Proposed Amendment</u></b> <i>(mandatory field)</i> This amendment proposes changes to paragraph 2.4.3 (and 2.4.2) of Schedule 3 of the STC to allow Parties to disclose specific data to Transmission Owners on an enduring basis for the purposes of transmission investment planning, specifically stability studies.</p>
<p><b>3. <u>Description of Issue or Defect that Proposed Amendment seeks to Address</u></b> <i>(mandatory field)</i> The current provisions of paragraph 2.4.3 of Schedule 3 will expire on 30 September 2006. However, there is a continuing need for this data to be provided to enable all Parties to meet their Licence obligations. It is therefore proposed that this data exchange is made permanent, but that the relevant sections of Schedule 3 are made more specific about the data that can be disclosed.</p>
<p><b>4. <u>Impact on the STC</u></b> <i>(information should be given where possible)</i> Changes to paragraph 2.4.3 of Schedule 3 are required. Minor changes to paragraph 2.4.2 are also proposed.  There are no other changes required to the STC.</p>
<p><b>5. <u>Impact on other frameworks e.g. CUSC, BSC</u></b> <i>(information should be given where possible)</i> None</p>
<p><b>6. <u>Impact on Core Industry Documentation</u></b> <i>(information should be given where possible)</i> None</p>
<p><b>7. <u>Impact on Computer Systems and Processes used by STC Parties</u></b> <i>(information should be given where possible)</i> None</p>
<p><b>8. <u>Details of any Related Modifications to Other Industry Codes</u></b> <i>(where known)</i> None</p>
<p><b>9. <u>Justification for Proposed Amendment with Reference to Applicable STC Objectives</u></b> <i>(mandatory field)</i> Amending the STC in this manner would mean that Transmission Owners would continue to be able to efficiently discharge the obligations imposed on them by transmission licences and the Act. It would also facilitate the development of an efficient, economical and coordinated system of electricity transmission.</p>

<b>Details of Proposer</b> Organisation's Name	National Grid Electricity Transmission plc
<b>Capacity in which the Amendment is being proposed</b> (i.e. STC Party or other Party as designated by the Authority pursuant to STC section B7.2.2.1 (b))	STC Party
<b>Details of Proposer's Representative</b> Name Organisation Telephone Number Email Address	Andrew Truswell National Grid Electricity Transmission plc 01926 656388 andrew.truswell@uk.ngrid.com
<b>Details of Representative's Alternate</b> Name Organisation Telephone Number Email Address	Ben Graff National Grid Electricity Transmission plc 01926 656312 ben.graff@uk.ngrid.com
<b>Attachments (Yes/No): Yes</b> If yes, title and number of pages of each attachment: (i) Indicative Legal Text (2 pages) (ii) JPC Evaluation Paper (20 pages)	

**Notes:**

- Those wishing to propose an Amendment to the STC should do so by filling in this "Amendment Proposal Form" that is based on the provisions contained in Section 7.2 of the STC.
- The Committee Secretary will check that the form has been completed, in accordance with the requirements of the STC, prior to submitting it to the Committee. If the Committee Secretary accepts the Amendment Proposal form as complete, then she/he will write back to the Proposer informing them of the reference number for the Amendment Proposal and the date on which the Committee will consider the Proposal. If, in the opinion of the Committee Secretary, the form fails to provide the information required in the STC, then he/she may reject the Proposal. The Committee Secretary will inform the Proposer of the rejection and report the matter to the Committee at their next meeting. The Committee can reverse the Committee Secretary's decision and if this happens the Committee Secretary will inform the Proposer.

The completed form should be returned to:

Shafiq Ullah  
STC Committee Secretary  
Commercial Frameworks  
National Grid Company plc  
National Grid House  
Warwick Technology Park  
Gallows Hill  
Warwick, CV34 6DA

Or via e-mail to: STCTeam@uk.ngrid.com

## Annex 2 - Proposed Text to Amend the STC

### Amend the following paragraphs in Schedule Three:

2.4.2 A Party may Disclose to a Transmission Owner:

- (a) where the Disclosing Party is NGET:
  - (i) information submitted to or by NGET under Appendix A to the Planning Code or OC2.4.2.1(a) in respect of any Relevant Unit;
  - (ii) NGET's forecast(s) of which Users will be connected to the Receiving Transmission Owner's Transmission System or connected within the Boundary of Influence of such Transmission System at any time or times during the current or following six Financial Years;
  - (iii) NGET's forecast(s) of the Ranking Order for the GB Transmission System, specifying:
    - a. relevant individual Generation Units connected to the Receiving Party's Transmission System or connected within the Boundary of Influence of such Transmission System; and
    - b. relevant aggregations of Generation Units connected outside of the Boundary of Influence of such Transmission System,at any time or times during the current or following six Financial Years;
  - (iv) the Ranking Order of all Generation Units which are Relevant Units and which NGET forecasts will be synchronised at the point in time when Demand on the GB Transmission System is at the forecast minimum in the current and following six Financial Years;
  - (v) the high level results of any economic studies undertaken for the purpose of assessing options for investment planning or Construction Projects, in each case involving the Receiving Transmission Owner, but not including the detailed content or analysis in such studies; and
- (b) ~~any Party may Disclose to a Transmission Owner~~ any changes which the Disclosing Party is planning to undertake to its Transmission System in the current or following six Financial Years and which will materially affect the planning or development of those parts of the Receiving Transmission Owner's Transmission System as are located within the Boundary of Influence of the Disclosing Party's Transmission System.

2.4.3 Without prejudice to sub-paragraph 2.4.2, ~~from the Code Effective Date to 30 September 2006 (inclusive), NGET a Party~~ may Disclose to a Transmission Owner:

- (a) ~~information submitted to or by NGET under Appendix A to the Planning Code or OC2.4.2.1(a) in respect of any User; and where the Disclosing Party is NGET:~~
  - (i) ~~information specified in Schedule Fourteen in respect of any User;~~

- (ii) lists of all Generation Units which NGET forecasts will be synchronised to meet specified levels of Demand on the GB Transmission System in the current and following six Financial Years, including, but not limited to:
- a. the forecast minimum Demand;
- b. 60% of the forecast peak Demand;
- c. the forecast peak Demand; and
- (b) any changes which the Disclosing Party is planning to undertake to its Transmission System in the current or following six Financial Years and which will materially affect the planning or development of the Receiving Transmission Owner's Transmission System~~the Ranking Order of all Generation Units which NGET forecasts will be synchronised at the point in time when Demand on the GB Transmission System is at the forecast minimum in the current and following six Financial Years.~~

Insert the following as Schedule Fourteen:

### SCHEDULE FOURTEEN

#### TRANSMISSION PLANNING DATA

1. Pursuant to Schedule Three, sub-paragraph 2.4.3, NGET may disclose to a Transmission Owner information submitted to or by NGET under Schedule 1 of the Data Registration Code in respect of any User, with the exception of the data items specified in the below extract:

<u>DATA DESCRIPTION</u>	<u>UNITS</u>	<u>DATA CAT.</u>
<u>Performance Chart at <b>Generating Unit</b> stator terminals</u>		<u>SPD</u>
<u><b>Output Usable</b> (on a monthly basis)</u>	<u>MW</u>	<u>SPD</u>
<u>GOVERNOR AND ASSOCIATED PRIME MOVER PARAMETERS</u>		
<u><b>Option 1</b></u>		
<u>BOILER &amp; STEAM TURBINE DATA</u>		
<u>Boiler time constant (Stored <b>Active Energy</b>)</u>	<u>S</u>	<u>DPD</u>
<u>HP turbine response ratio: (Proportion of <b>Primary Response</b> arising from HP turbine)</u>	<u>%</u>	<u>DPD</u>
<u>HP turbine response ratio: (Proportion of <b>High Frequency Response</b> arising from HP turbine)</u>	<u>%</u>	<u>DPD</u>
<u><b>Option 2</b></u>		
<u><b>All Generating Units</b></u>		
<u>Governor Deadband</u>		

- <u>Maximum Setting</u>	<u>±Hz</u>	<u>DPD</u>
- <u>Normal Setting</u>	<u>±Hz</u>	<u>DPD</u>
- <u>Minimum Setting</u>	<u>±Hz</u>	<u>DPD</u>
<b><u>Steam Units</u></b>		
<u>Reheater Time Constant</u>	<u>sec</u>	<u>DPD</u>
<u>Boiler Time Constant</u>	<u>sec</u>	<u>DPD</u>
<u>HP Power Fraction</u>	<u>%</u>	<u>DPD</u>
<u>IP Power Fraction</u>	<u>%</u>	<u>DPD</u>
<b><u>Gas Turbine Units</u></b>		
<u>Waste Heat Recovery Boiler Time Constant</u>		
<b><u>UNIT CONTROL OPTIONS*</u></b>		
<u>Maximum droop</u>	<u>%</u>	<u>DPD</u>
<u>Minimum droop</u>	<u>%</u>	<u>DPD</u>
<u>Maximum frequency deadband</u>	<u>±Hz</u>	<u>DPD</u>
<u>Normal frequency deadband</u>	<u>±Hz</u>	<u>DPD</u>
<u>Minimum frequency deadband</u>	<u>±Hz</u>	<u>DPD</u>
<u>Maximum Output deadband</u>	<u>±MW</u>	<u>DPD</u>
<u>Normal Output deadband</u>	<u>±MW</u>	<u>DPD</u>
<u>Minimum Output deadband</u>	<u>±MW</u>	<u>DPD</u>
<u>Frequency settings between which</u> <u>Unit Load Controller droop applies:</u>		
<u>Maximum</u>	<u>Hz</u>	<u>DPD</u>
<u>Normal</u>	<u>Hz</u>	<u>DPD</u>
<u>Minimum</u>	<u>Hz</u>	<u>DPD</u>
<u>Sustained response normally selected</u>	<u>Yes/No</u>	<u>DPD</u>
<u>(Power Park Modules)</u>		
<u>Performance Chart of a at <b>Power Park Module</b></u> <u>at the connection point</u>		<u>SPD</u>
<u><b>Output Usable</b> (on a monthly basis)</u>	<u>MW</u>	<u>SPD</u>
<b><u>DC CONVERTER STATION DATA</u></b>		
<b><u>ACTIVE POWER TRANSFER CAPABILITY</u></b> <u>(PC.A.3.2.2)</u>		
<u>Import MW available in excess of <b>Registered</b></u> <u><b>Import Capacity.</b></u>	<u>MW</u>	<u>SPD</u>
<u>Time duration for which MW in excess of</u> <u><b>Registered Import Capacity</b> is available</u>	<u>Min</u>	<u>SPD</u>
<u>Export MW available in excess of <b>Registered</b></u> <u><b>Capacity.</b></u>	<u>MW</u>	<u>SPD</u>
<u>Time duration for which MW in excess of</u> <u><b>Registered Capacity</b> is available</u>	<u>Min</u>	<u>SPD</u>

<u>LOADING PARAMETERS [PC.A.5.4.3.3]</u>		
<u>MW Export</u>		
<u>Nominal loading rate</u>	<u>MW/s</u>	<u>DPD</u>
<u>Maximum (emergency) loading rate</u>	<u>MW/s</u>	<u>DPD</u>
<u>MW Import</u>		
<u>Nominal loading rate</u>	<u>MW/s</u>	<u>DPD</u>
<u>Maximum (emergency) loading rate</u>	<u>MW/s</u>	<u>DPD</u>

**Insert the following definition in Section J:**

**“Data Registration Code”**      that part of the Grid Code that is identified as the Data Registration Code;

## **Annex 3 - JPC Evaluation**

### **Schedule 3 Paragraph 2.4.3**

#### **Summary**

1. This document concerns schedule 3 of the STC, and specifically paragraph 2.4.3, which is due to expire on 30<sup>th</sup> September 2006. The document summarises certain obligations placed on the Transmission Licensees and examines four approaches to fulfilling these obligations. A final recommendation is made which requires an amendment to paragraph 2.4.3 to allow for the enduring exchange of certain demand, generator and investment planning network data.

#### **Introduction**

2. Paragraph 2.4.3 in Schedule 3 of the STC is due to expire on 30<sup>th</sup> September 2006. The STC Committee has asked the Joint Planning Committee (JPC) to examine the impact of this clause. This document summarises the JPC's position on this clause.

#### **Background to Paragraph 2.4.3**

3. Schedule 3 of the STC sets out the information and data permitted to be disclosed by a Party to a Transmission Owner in accordance with Section F of the STC. During the drafting of the STC, Ofgem imposed a 'time limit' on the STC provisions, which allow Investment Planning Data to be provided by National Grid to a Transmission Owner<sup>5</sup>. The existing provisions of paragraph 2.4.3 of Schedule 3, which permit National Grid to provide certain data to Transmission Owners relating to Generation Units outside of their Boundary of Influence, have been hard coded to become obsolete on 30<sup>th</sup> September 2006. In the interim period, Ofgem expect National Grid and Transmission Owners to liaise to develop a more enduring set of arrangements in this area.
4. The reason that a time limit was imposed on the provision of this information, was the fact that some Investment Planning information, whilst of great value in facilitating the efficient discharge of a Transmission Owner's License obligations, has the potential to theoretically prejudice the facilitation of competition in generation and supply, if that Transmission Licensee has associated generation and supply interests. Ofgem therefore suggested that the licensees consider further whether it may be more appropriate for National Grid to carry out system stability studies and/or whether the network model made available to Transmission Owners should, in relation to some parts of the system, be an equivalent model. However, Ofgem noted that the use of equivalence models may be highly problematic, and accepted that the result of the review may be that the process put in place from go-live is the most appropriate enduring process.
5. At the November Meeting of the JPC, it was agreed that such a review of Schedule 3 would commence in early 2006. The review would be conducted by an expert group, consisting of representatives from the TOs and National Grid. The STC Committee, 11<sup>th</sup> January 2006, issued a further guidance note on this process.

---

<sup>5</sup> Ofgem Conclusion Document – Information Exchange Under the STC (March 2005)

**Obligations on the Transmission Owners (TOs)**

6. Transmission Owners have various obligations to fulfil, including:
  - a) Under the Electricity Act 1989, holders of a transmission licence have a duty to develop and maintain an efficient, co-ordinated and economical system of electricity transmission.
  - b) Each Company's Transmission Licence further requires them to plan and develop their transmission systems in accordance with the GB Security and Quality of Supply Standards (GBSQSS) and STC.
  - c) The GBSQSS (under paragraph 4.8) requires the transmission system to be planned such that there shall not be system instability for conditions on the GB transmission system which ought to be reasonably expected to arise in the course of a year of operation.
  - d) In accordance with the STC each Transmission Owner shall develop and maintain a transmission investment plan in respect of the current and each of the following six financial years.
7. To undertake a stability study the following information is required for the entire system under consideration:
  - a) Network topology and connectivity including branch parameters.
  - b) Reactive compensation system parameters and relevant control system details.
  - c) Demand
  - d) Generation – connectivity, location and type.
  - e) Generator dynamic parameters.
  - f) Details of relevant generator control systems.
8. Therefore, in order to meet its obligations to plan in accordance with the GBSQSS, and assess system stability, each licensee requires information on conditions on the GB transmission system which ought to be reasonably expected to arise in the course of a year of operation, including:
  - a) The system data described above in line with each transmission company's seven year investment plan. For stability studies each company will need an accurate representation of the whole GB network.
  - b) Generation and demand patterns for a variety of demand conditions. In practice this may cover, for example, forecast summer minimum, 60% and 100% of forecast ACS peak demand levels for a specific year. (Traditionally, the GB power system stability problem is considered to be most onerous under minimum system demand conditions when fewer machines are running and the overall synchronising power is lower. Importantly, due to the higher network voltage profile seen under this condition, those machines that are running may be close to unity power factor or operating in the leading mode resulting in a lower stability margin. Additionally, past experience has indicated that the worst case for stability on the Anglo – Scottish interconnector occurred at approximately 60% demand.)

- c) Traditionally dynamic stability and transient stability are issues for synchronous generators whereas voltage stability becomes an increasing problem for wind farms due to their reliance on induction generator technology. In view of the growth in renewable generation, in particular wind generation and subsequent significant changes in the disposition of generation, it would be considered prudent to look at a range of demand conditions. A corresponding list of generators that would be running to meet this demand would also be required. A specific ranking order of these generators would not be required.

### **Stability Analysis pre- BETTA**

9. Before the introduction of BETTA, the Scottish Transmission Licensees had to comply with their individual licence standards and the Scottish Grid Code. Joint system stability studies were carried out under the British Grid Systems Agreement (BGSA). The BGSA was an agreement between the three GB Transmission Licensees, NGC, SHETL and SPT. The main objective of the agreement was to manage the interconnection between the Licensees grid systems and to maintain the integrity of the whole GB Grid System.
10. BGSA Code 3 placed a requirement on the Parties to plan and develop their respective Grid Systems to sustain the Interconnection capability (both the Anglo-Scottish Interconnector and the SHETL-SPT Interconnector circuits). Code 3 also defined the data to be transferred between the Parties to undertake the necessary planning studies. A sub-committee, referred to as the Joint Interconnector Planning Group (JIPG), was established to advise the British Grid System Committee (BGSC) on the co-ordinated planning and development of the Interconnector circuits.
11. Each year the JIPG undertook benchmark thermal, voltage and transient stability studies to track the Interconnector capacity as new developments were introduced to each of the grid networks. The studies were carried out at various demand levels (typically 40%, 60%, 80% and 100% of system maximum demand) and over a number of study years. These co-ordinated studies involved the exchange of transmission data for the whole GB system and considerable time was invested in making sure the dynamic representation of plant and controllers were accurately modelled in each company's computer system. This co-ordinated approach allowed verification of data and permitted the Parties to investigate the cause of any differences in the study results. The studies carried out by each party were compared and where agreement was obtained this gave a high degree of confidence in the study results. Through this process it became evident that modelling the whole GB system was important to the outcome of transient stability studies. One example was the representation of the SVCs in the south of England, which proved to have a significant impact on the stability of generators in Scotland for critical flows on the Anglo-Scottish Interconnector.
12. Confidentiality of data was dealt with under various sections of the Transmission Licence, Public Electricity Supply Licences, Grid Codes, Distribution Codes and the BGSA itself. The BGSA had an extensive clause, defining how NGC, SHETL and SPT could use any information or data supplied to and acquired from the other Parties in performing the permitted activities. This allowed for the exchange of complete network, demand and generation data and the use of this information was covered under a confidentiality agreement.

**Approaches to developing paragraph 2.4.3 of Schedule 3 of the STC**

13. The following four alternatives to the existing paragraph 2.4.3 have been considered and are discussed in detail below:

- a) Take no action (let the clause lapse).
- b) Use dynamic equivalents for stability studies.
- c) Use SYS networks instead of Investment Planning networks.
- d) Revise paragraph 2.4.3 to allow the exchange of specific information needed for stability studies.

**Option a - Do nothing (i.e. let the clause lapse):**

14. If the clause were to lapse, then NGET would no longer be able to pass the specified data to the Scottish TOs. If this data were no longer transferred, then the TOs would no longer be able to fulfil their licence obligations to carry out stability studies, and they would need to be relieved of their obligations to carry out stability studies under the GBSQSS. This would require a change to the Scottish TOs' Transmission Licences.

15. Further, if stability studies are not completed at all as part of the Investment Planning process, then any stability problems would have to be addressed in operational timescales, which has potentially severe constraint cost implications. For example, in an extreme case, a new generator may have to be permanently constrained off due to stability concerns. The impact of this would be more severe if there was a shortage of generation in the future, putting the system under even greater stress.

16. An alternative approach to this would be for NGET to carry out stability studies and plan appropriate investments for the whole of GB. This would, however, undermine the prime obligation of the TOs to ensure compliance with GBSQSS and plan and develop their system in an efficient, co-ordinated and economical manner. For example, investment solutions often cover several non-compliance issues, however, investments may no longer be co-ordinated if different companies had responsibility for different aspects of compliance (e.g. an SVC can address both voltage and stability issues).

17. Therefore, letting paragraph 2.4.3 lapse is not an acceptable option, because the Scottish Transmission Licensees would no longer be able to meet their license conditions.

**Option b - Use of dynamic equivalents**

18. Compared to carrying out a detailed stability study on a full network, the use of equivalents has the following disadvantages and problems:

- a) Dynamic equivalents are less accurate because of the very large number of non-linear variables involved (leading to potential over or under investment).
- b) With equivalents, it is difficult to determine the exact nature and cause of an instability condition and therefore potential reinforcement solutions may be ill judged. Such an approach could lead to either over or under investment.
- c) The use of equivalents assumes that there are only network solutions to stability problems, whereas in reality these could be rectified using alternative control system solutions employed on generating plant, which may provide a cheaper solution.

- d) An equivalent is specific to one single scenario and does not allow for sensitivity analysis related to variations in the generation and demand pattern.
  - e) The skills required to produce equivalents are specialised and the process is very resource intensive. Equivalents would need to be set up to cover a wide range of scenarios and these would each need to be fully validated against a range of detailed stability studies.
19. To summarise, the use of dynamic equivalents carries a high risk of inefficient (or even non-compliant) network investments, planned by using system models in which the Transmission Owners would have reduced confidence. Therefore, the use of dynamic equivalents is not considered an acceptable alternative.

#### Option c - Use of SYS networks instead of Investment Planning networks

20. As currently written, STCP 22-1 assumes the creation of hybrid networks for all Investment Planning studies other than the summer minimum. These hybrid networks are created by joining an Investment Planning network to a SYS network outside the Boundary of Influence.
21. Generally, a Transmission Owner's Investment Planning network differs considerably from the SYS networks for the next seven years. For example, SYS networks may contain reinforcements that have an impact on stability, but would not be contained in an Investment Planning network. A specific example of this is the fourth England-Scotland interconnector circuit, which has a significant impact on stability. This reinforcement would be included in a SYS dataset but not an Investment Planning network. In particular, there is considerable risk that non-optimal solutions to stability problems could be proposed or that potential stability issues are not assessed and corrected adequately.
22. Previous studies to determine the Anglo-Scottish Interconnector capacity, carried out under the BGSA, did use SYS networks. However, it should be noted that pre-Betta the Interconnector capability was governed under a contractual/commercial relationship between the three Transmission Licensees rather than a requirement to satisfy the GB security and quality of supply standard as is now required. The purpose of past benchmarking studies was **not** therefore to identify necessary investments based on GB power flows, rather it was to monitor known stability, voltage and thermal limits for the system over the next year or two to ensure no erosion of capability was likely to occur due to developments in each Licensee's area. For this purpose it was adequate to study the Interconnector capability a couple of years out using the SYS networks where there was little divergence between the SYS networks and the Investment Planning view. However, it was recognised that the SYS networks would not be adequate for the full planning cycle.
23. It should also be noted that as currently written, STCP 22-1 assumes the use of Investment Planning networks, without the use of hybrids, for the study of the summer minimum condition, and is therefore not workable under the current drafting of Schedule 3.
24. Finally, the current processes for the exchange of SYS networks do not allow for the inclusion of generator dynamic data or any control system models, so these networks would not be adequate for stability studies.
25. In summary, the use of SYS networks for stability studies in planning time-scales is not considered an acceptable alternative.

Option d - Revise paragraph 2.4.3 to include only the specific information and data needed for stability studies

26. Based on the above information, the preferred approach would be to amend paragraph 2.4.3 of the STC to specifically target the minimum data required for the Transmission Licensees to be able to undertake stability studies. The following revisions are proposed:
- a) List out specific information and data from Appendix A of the GB Grid Code Planning Code that is specifically required for stability studies. This will take out reference to any demand, user data and generator data that is not required specifically for stability studies. In terms of data requirements, the Data Registration Code summarises all data requirements under the Grid Code. It is therefore considered appropriate to quote those data items required from the Data Registration Code and include them as an Appendix to the STC rather than list large sections of Appendix A of the Planning Code. See Appendix 1 for proposed information list. The advantage of this approach is that the exchange of many of the potentially commercially sensitive data items will no longer be required (in its existing form, paragraph 2.4.3 allows the disclosure of all data items listed in appendix A to the Planning Code and in OC2.4.2.1(a)).
  - b) Change the term ranking order, to become a list, in no particular order, of generation units which NGET forecasts to be synchronised to meet a specified demand. These demand levels will include the minimum, 60% of peak demand and ACS peak demand on the GB Transmission System. The TOs should also be able to request sensitivities on the lists provided.
  - c) Add the exchange of Investment Planning network data at the time of minimum, 60% and ACS peak demand on the GB Transmission System (this is additional to what is currently allowed under schedule 3).
  - d) Take out reference to the information referred to in OC2.4.2.1(a) as this is not required.
27. This is the preferred approach as it allows all the Transmission Licensees to carry out detailed stability studies as required by their transmission licenses. Further, the information that would be exchanged is significantly reduced and excludes most of the information that could be considered commercially sensitive.

**Recommendations**

28. The JPC recommends that paragraph 2.4.3 of Schedule 3 is amended to allow for the enduring exchange of certain demand, generator and investment planning network data, as detailed in Option d above.

### Appendix 1 – user data required to be transferred for stability studies

The Data Registration Code comprises of 15 Schedules and is a summary of all data required under the Grid Code. In order for the TOs to fulfil their obligation under the Transmission Licence and GBSQSS to carry out stability studies, only a subset of this data will be required from Schedule 1 of the DRC. No data items are required from Schedules 2 to 15 of the DRC.

The following tables are extracted from DRC Schedule 1. None of the data required is believed to be commercially confidential in respect of generation market conditions. There may however be an issue with respect to providing Users data, which is seen as intellectual property, especially amongst wind turbine manufacturers.

**DATA REGISTRATION CODE****SCHEDULE 1****GENERATING UNIT (OR CCGT MODULE) TECHNICAL DATA**

DATA DESCRIPTION	UNITS	DAT A CAT.	GENERATING UNIT (OR CCGT MODULE, AS THE CASE MAY BE)						
			G1	G2	G3	G4	G5	G6	STN
Rated MVA	MVA	<b>SPD+</b>							
Rated MW	MW	<b>SPD+</b>							
Rated terminal voltage	kV	<b>DPD</b>							
Turbo-Generator inertia constant (for synchronous machines)	MW secs /MVA	<b>SPD+</b>							
Normal auxiliary load supplied by the <b>Generating Unit</b> at rated MW output	MW Mvar	<b>DPD</b> <b>DPD</b>							
Rated field current at rated MW and Mvar output and at rated terminal voltage	A	<b>DPD</b>							
<i>Field current open circuit saturation curve (as derived from appropriate manufacturers' test certificates):</i>									
120% rated terminal volts	A	<b>DPD</b>							
110% rated terminal volts	A	<b>DPD</b>							
100% rated terminal volts	A	<b>DPD</b>							
90% rated terminal volts	A	<b>DPD</b>							
80% rated terminal volts	A	<b>DPD</b>							
70% rated terminal volts	A	<b>DPD</b>							
60% rated terminal volts	A	<b>DPD</b>							
50% rated terminal volts	A	<b>DPD</b>							
<b><u>IMPEDANCES:</u></b> (Unsaturated)									
Direct axis synchronous reactance	% on MVA	<b>DPD</b>							
Direct axis transient reactance	% on MVA	<b>SPD+</b>							
Direct axis sub-transient reactance	% on MVA	<b>DPD</b>							
Quad axis synch reactance	% on MVA	<b>DPD</b>							
Quad axis sub-transient reactance	% on MVA	<b>DPD</b>							
Stator leakage reactance	% on MVA	<b>DPD</b>							
Armature winding direct current Resistance.	% on MVA	<b>DPD</b>							
In Scotland, negative sequence resistance	% on MVA	<b>DPD</b>							

Note: - the above data item relating to armature winding direct-current resistance need only be provided by **Generators** in relation to **Generating Units** commissioned after 1st March 1996 and in cases where, for whatever reason, the **Generator** is aware of the value of the data item.

SCHEDULE 1

DATA DESCRIPTION	UNITS	DAT A CAT.	GENERATING UNIT OR STATION DATA						
			G 1	G2	G3	G 4	G 5	G 6	STN
<u>TIME CONSTANTS</u> (Short-circuit and Unsaturated)									
Direct axis transient time constant	S	<b>DPD</b>							
Direct axis sub-transient time Constant	S	<b>SPD</b>							
Quadrature axis sub-transient time Constant	S	<b>DPD</b>							
Stator time constant	S	<b>DPD</b>							
<u>GENERATING UNIT STEP-UP TRANSFORMER</u>									
Rated MVA	MVA	<b>SPD</b> +							
Voltage Ratio	-	<b>DPD</b>							
Positive sequence reactance: Max tap	% on MVA	<b>SPD</b> +							
Min tap	% on MVA	<b>SPD</b> +							
Nominal tap	% on MVA	<b>SPD</b> +							
Positive sequence resistance: Max tap	% on MVA	<b>DPD</b>							
Min tap	% on MVA	<b>DPD</b>							
Nominal tap	% on MVA	<b>DPD</b>							
Tap change range	+% / -%	<b>DPD</b>							
Tap change step size	%	<b>DPD</b>							
Tap changer type, on-load or off-circuit	On/Off	<b>DPD</b>							
<u>EXCITATION:</u>									

Note: The data items requested under Option 1 below may continue to be provided by **Generators** in relation to **Generating Units** on the **System** at 9 January 1995 (in this paragraph, the "relevant date") or they may provide the new data items set out under Option 2. **Generators** must supply the data as set out under Option 2 (and not those under Option 1) for **Generating Unit** excitation control systems commissioned after the

relevant date, those **Generating Unit** excitation control systems recommissioned for any reason such as refurbishment after the relevant date and **Generating Unit** excitation control systems where, as a result of testing or other process, the **Generator** is aware of the data items listed under Option 2 in relation to that **Generating Unit**.

<b>Option 1</b>									
DC gain of <b>Excitation Loop</b>									
Max field voltage	V	DPD							
Min field voltage	V	DPD							
Rated field voltage	V	DPD							
Max rate of change of field volts:									
Rising	V/Sec	DPD							
Falling	V/Sec	DPD							
Details of <b>Excitation Loop</b>	Diagram	DPD	(please						
Described in block diagram form showing transfer functions of individual elements			attach)						

**SCHEDULE 1**

DATA DESCRIPTION	UNITS	DAT A CAT.	GENERATING UNIT OR STATION DATA						
			G 1	G2	G3	G4	G5	G6	STN
<b><u>Option 2</u></b>									
<b>Exciter</b> category, e.g. <b>Rotating Exciter</b> , or <b>Static Exciter</b> etc	Text	SPD							
<b><u>Excitation System Nominal Response</u></b>	sec <sup>-1</sup>	DPD							
<b>Rated Field Voltage</b> $V_E$	V	DPD							
<b>No-load Field Voltage</b> $U_{fN}$	V	DPD							
<b><u>Excitation System On-Load Positive Ceiling Voltage</u></b> $U_{pL+}$	V	DPD							
<b><u>Excitation System No-Load Positive Ceiling Voltage</u></b> $U_{pO+}$	V	DPD							
<b><u>Excitation System No-Load Negative Ceiling Voltage</u></b> $U_{pO-}$	V	DPD							
<b><u>Power System Stabiliser (PSS)</u></b>	Yes/No	SPD							
Fitted									
Details of <b>Excitation System</b> (including <b>PSS</b> if fitted) described in block diagram form showing transfer functions	Diagram	DPD							

of individual elements.

**SCHEDULE 1**

DATA DESCRIPTION	UNITS	DATA CAT.	GENERATING UNIT OR STATION DATA						
			G1	G2	G3	G4	G5	G6	STN
<b>GOVERNOR AND ASSOCIATED PRIME MOVER PARAMETERS</b>									
<p><b>Note:</b> The data items requested under Option 1 below may continue to be provided by <b>Generators</b> in relation to <b>Generating Units</b> on the <b>System</b> at 9 January 1995 (in this paragraph, the "relevant date") or they may provide the new data items set out under Option 2. <b>Generators</b> must supply the data as set out under Option 2 (and not those under Option 1) for <b>Generating Unit</b> governor control systems commissioned after the relevant date, those <b>Generating Unit</b> governor control systems recommissioned for any reason such as refurbishment after the relevant date and <b>Generating Unit</b> governor control systems where, as a result of testing or other process, the <b>Generator</b> is aware of the data items listed under Option 2 in relation to that <b>Generating Unit</b>.</p>									
<b>Option 1</b>									
<u>GOVERNOR PARAMETERS (REHEAT UNITS)</u>									
HP Governor average gain	MW/Hz	DPD							
Speeder motor setting range	Hz	DPD							
HP governor valve time constant	S	DPD							
HP governor valve opening limits		DPD							
HP governor valve rate limits		DPD							
Re-heat time constant (stored <b>Active Energy</b> in reheater)	S	DPD							
IP governor average gain	MW/Hz	DPD							
IP governor setting range	Hz	DPD							
IP governor time constant	S	DPD							
IP governor valve opening limits		DPD							
IP governor valve rate limits		DPD							
Details of acceleration sensitive elements HP & IP in governor loop		DPD	(please attach)						
Governor block diagram showing transfer functions of individual elements		DPD	(please attach)						
<u>GOVERNOR (Non-reheat steam and Gas Turbines)</u>									
Governor average gain	MW/Hz	DPD							
Speeder motor setting range		DPD							
Time constant of steam or fuel governor valve	S	DPD							
Governor valve opening limits		DPD							
Governor valve rate limits		DPD							
Time constant of turbine	S	DPD							
Governor block diagram		DPD	(please attach)						

**SCHEDULE 1**

DATA DESCRIPTION	UNITS	DATA CAT.	GENERATING UNIT OR STATION DATA						
			G1	G2	G3	G4	G5	G6	ST N
End of Option 1									
<b>Option 2</b>									
<b><u>All Generating Units</u></b>									
Governor Block Diagram showing transfer function of individual elements including acceleration sensitive elements		<b>DPD</b>							
Governor Time Constant	Sec	<b>DPD</b>							
Speeder Motor Setting Range	%	<b>DPD</b>							
Average Gain	MW/H z	<b>DPD</b>							
<b><u>Steam Units</u></b>									
HP Valve Time Constant	sec	<b>DPD</b>							
HP Valve Opening Limits	%	<b>DPD</b>							
HP Valve Opening Rate Limits	%/sec	<b>DPD</b>							
HP Valve Closing Rate Limits	%/sec	<b>DPD</b>							
HP Turbine Time Constant	sec	<b>DPD</b>							
IP Valve Time Constant	sec	<b>DPD</b>							
IP Valve Opening Limits	%	<b>DPD</b>							
IP Valve Opening Rate Limits	%/sec	<b>DPD</b>							
IP Valve Closing Rate Limits	%/sec	<b>DPD</b>							
IP Turbine Time Constant	sec	<b>DPD</b>							
LP Valve Time Constant	sec	<b>DPD</b>							
LP Valve Opening Limits	%	<b>DPD</b>							
LP Valve Opening Rate Limits	%/sec	<b>DPD</b>							
LP Valve Closing Rate Limits	%/sec	<b>DPD</b>							
LP Turbine Time Constant	sec	<b>DPD</b>							
Reheater Time Constant	sec	<b>DPD</b>							

# Where the generating unit governor does not have a selectable deadband facility, then the actual value of the deadband need only be provided.

**SCHEDULE 1**

DATA DESCRIPTION	UNITS	DATA CAT.	GENERATING UNIT OR STATION DATA						
			G1	G2	G3	G4	G5	G6	STN
<b><u>Gas Turbine Units</u></b>									
Inlet Guide Vane Time Constant	sec	DPD							
Inlet Guide Vane Opening Limits	%	DPD							
Inlet Guide Vane Opening Rate Limits	%/sec	DPD							
Inlet Guide Vane Closing Rate Limits	%/sec	DPD							
Fuel Valve Time Constant	sec	DPD							
Fuel Valve Opening Limits	%	DPD							
Fuel Valve Opening Rate Limits	%/sec	DPD							
Fuel Valve Closing Rate Limits	%/sec	DPD							
<b><u>Hydro Generating Units</u></b>									
Guide Vane Actuator Time Constant	sec	DPD							
Guide Vane Opening Limits	%	DPD							
Guide Vane Opening Rate Limits	%/sec	DPD							
Guide Vane Closing Rate Limits	%/sec	DPD							
Water Time Constant	sec	DPD							
	End of Option 2								
<b><u>UNIT CONTROL OPTIONS*</u></b>									
Normal droop	%	DPD							

**SCHEDULE 1**

DATA DESCRIPTION	UNITS	DATA CAT.	POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)						
			G1	G2	G3	G4	G5	G6	ST N
<b>Power Park Module Rated MVA</b> <b>Power Park Module Rated MW</b>	MVA MW	SPD+ SPD+							
Number & Type of <b>Power Park Units</b> within each <b>Power Park Module</b>									
<b>Power Park Unit Model</b> - A validated mathematical model in accordance with PC.5.4.2 (a)	Transfer function block diagram and algebraic equations, simulation	DPD							

DATA DESCRIPTION	UNITS	DATA CAT.	POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)							
			G1	G2	G3	G4	G5	G6	ST N	
	and measured test results									
<b>Power Park Unit Data</b> (where applicable)										
Rated MVA	MVA	<b>SPD+</b>								
<b>Rated MW</b>	MW	<b>SPD+</b>								
Rated terminal voltage	V	<b>SPD+</b>								
Inertia constant at synchronous speed	MW secs /MVA	<b>SPD+</b>								
Stator Resistance.	% on MVA	<b>DPD</b>								
Stator Reactance.	% on MVA	<b>SPD+</b>								
Magnetising Reactance	% on MVA	<b>SPD+</b>								
Rotor Resistance (at starting).	% on MVA	<b>DPD</b>								
Rotor Resistance (at rated running)	% on MVA	<b>SPD+</b>								
Rotor Reactance (at starting).	% on MVA	<b>DPD</b>								
<i>Rotor Reactance (at rated running)</i>	% on MVA	<b>SPD</b>								
<i>Inertia constant of the wind turbine rotor</i>	MW secs /MVA	<b>DPD</b>								
<i>Inertia constant of the generator rotor</i>	MW secs /MVA	<b>DPD</b>								
<i>Shaft stiffness</i>	Nm / electrical radian	<b>DPD</b>								

**SCHEDULE 1**

DATA DESCRIPTION	UNITS	DATA CAT.	POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)							
			G1	G2	G3	G4	G5	G6	ST N	
<i>Minimum generator rotor speed (Doubly Fed Induction Generators)</i>	RPM	<b>SPD+</b>								
<i>Maximum generator rotor speed (Doubly Fed Induction Generators)</i>	RPM	<b>SPD+</b>								
<i>The optimum generator rotor speed versus wind speed</i>	tabular format	<b>DPD</b>								
<i>Power Converter Rating (Doubly Fed Induction Generators)</i>	MVA	<b>SPD+</b>								
<i>The rotor power coefficient (<math>C_p</math>) versus tip speed ratio (<math>\lambda</math>) curves for a range of blade angles (where applicable)</i>	Diagram + tabular format	<b>DPD</b>								
<i>The electrical power output versus generator rotor speed for a range of wind speeds over the entire operating range of the <b>Power Park Unit</b>.</i>	Diagram + tabular format	<b>DPD</b>								
The blade angle versus wind speed curve	Diagram +	<b>DPD</b>								

DATA DESCRIPTION	UNITS	DATA CAT.	POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)						
			G1	G2	G3	G4	G5	G6	ST N
<p>The electrical power output versus wind speed over the entire operating range of the <b>Power Park Unit</b>.</p> <p>Transfer function block diagram, parameters and description of the operation of the power electronic converter (where applicable).</p> <p>For a <b>Power Park Unit</b> consisting of a synchronous machine in combination with a back to back <b>DC Converter</b>, or for a <b>Power Park Unit</b> not driven by a wind turbine, the data to be supplied shall be agreed with <b>NGET</b> in accordance with PC.A.7.</p>	tabular format								
	Diagram + tabular format	<b>DPD</b>							
	Diagram	<b>DPD</b>							

**SCHEDULE 1**

DATA DESCRIPTION	UNITS	DATA CAT.	POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)						
			G1	G2	G3	G4	G5	G6	STN
<p>Torque / Speed and blade angle control systems and parameters</p> <p>For the <b>Power Park Unit</b>, details of the torque / speed controller and blade angle controller in the case of a wind turbine and power limitation functions (where applicable) described in block diagram form showing transfer functions and parameters of individual elements</p>	Diagram	<b>DPD</b>							
<p>Voltage/Reactive Power/Power Factor control system parameters</p> <p>For the <b>Power Park Unit</b> and <b>Power Park Module</b> details of <b>Voltage/Reactive Power/Power Factor</b> controller (and <b>PSS</b> if fitted) described in block diagram form including parameters showing transfer functions of individual elements.</p>	Diagram	<b>DPD</b>							
<p><b>Frequency</b> control system parameters</p> <p>For the <b>Power Park Unit</b> and <b>Power Park Module</b> details of the <b>Ffrequency</b> controller</p>	Diagram	<b>DPD</b>							

<p>described in block diagram form showing transfer functions and parameters of individual elements.</p> <p>As an alternative to PC.A.5.4.2 (a), (b), (c), (d), (e) and (f), is the submission of a single complete model that consists of the full information required under PC.A.5.4.2 (a), (b), (c), (d) (e) and (f) provided that all the information required under PC.A.5.4.2 (a), (b), (c), (d), (e) and (f) individually is clearly identifiable.</p>	Diagram	DPD							
--	---------	-----	--	--	--	--	--	--	--

**SCHEDULE 1**

**DC CONVERTER STATION TECHNICAL DATA**

Data Description	Units	Data Category	DC Converter Station Data
<b>DC CONVERTER STATION DATA</b>			
Number of poles, i.e. number of <b>DC Converters</b>	Text		
Pole arrangement (e.g. monopole or bipole)	Text	<b>SPD+</b>	
Details of each viable operating configuration	Diagram	<b>SPD+</b>	
Configuration 1	Diagram		
Configuration 2	Diagram	<b>SPD+</b>	
Configuration 3	Diagram		
Configuration 4	Diagram		
Configuration 5	Diagram		
Configuration 6	Diagram		
Remote ac connection arrangement	Diagram	<b>SPD</b>	
	Diagram		

**SCHEDULE 1**

Data Description	Units	Data Category	Operating Configuration					
			1	2	3	4	5	6
<b>DC CONVERTER STATION DATA</b>								
<b>DC Converter</b> Type (e.g. current or Voltage source)	Text	<b>SPD</b>						
<b>Rated MW</b> import per pole [PC.A.3.3.1]	MW	<b>SPD+</b>						
<b>Rated MW</b> export per pole [PC.A.3.3.1]	MW	<b>SPD+</b>						
<b>DC CONVERTER TRANSFORMER [PC.A.5.4.3.1]</b>								
Rated MVA	MVA	<b>DPD</b>						
Winding arrangement	KV	<b>DPD</b>						
Nominal primary voltage	KV	<b>DPD</b>						
Nominal secondary (converter-side) voltage(s)		<b>DPD</b>						
Positive sequence reactance	% on	<b>DPD</b>						
Maximum tap	MVA	<b>DPD</b>						
Nominal tap	% on							
Minimum tap	MVA	<b>DPD</b>						
Positive sequence resistance	% on	<b>DPD</b>						
Maximum tap	MVA	<b>DPD</b>						
Nominal tap		<b>DPD</b>						
Minimum tap	% on							
Tap change range	MVA	<b>DPD</b>						
Number of steps	% on							
	MVA							
	% on							
	MVA							
	% on							
	MVA							
	+% / -%							

**SCHEDULE 1**

Data Description	Units	Data Category	Operating configuration					
			1	2	3	4	5	6
<p><b>DC NETWORK [PC.A.5.4.3.1 (c)]</b></p> <p>Rated DC voltage per pole Rated DC current per pole</p> <p>Details of the <b>DC Network</b> described in diagram form including resistance, inductance and capacitance of all DC cables and/or DC lines. Details of any line reactors (including line reactor resistance), line capacitors, DC filters, earthing electrodes and other conductors that form part of the <b>DC Network</b> should be shown.</p>	<p>KV A</p> <p>Diagram</p>	<p><b>DPD</b> <b>DPD</b> <b>DPD</b></p>						
<p><b>DC CONVERTER STATION AC HARMONIC FILTER AND REACTIVE COMPENSATION EQUIPMENT [PC.A.5.4.3.1 (d)]</b></p> <p>For all switched reactive compensation equipment</p> <p>Total number of AC filter banks Diagram of filter connections Type of equipment (e.g. fixed or variable) Capacitive rating; or Inductive rating; or Operating range</p> <p><b>Reactive Power</b> capability as a function of various MW transfer levels</p>	<p>Diagram</p> <p>Text</p> <p>Diagram</p> <p>Text</p> <p>Mvar</p> <p>Mvar</p> <p>Mvar</p> <p>Table</p>	<p><b>SPD</b> <b>SPD</b> <b>SPD</b> <b>DPD</b> <b>DPD</b> <b>DPD</b> <b>DPD</b></p>						

**SCHEDULE 1**

Data Description	Units	Data Category	Operating configuration					
			1	2	3	4	5	6
<b>CONTROL SYSTEMS [PC.A.5.4.3.2]</b>								

<p>Static <math>V_{DC} - P_{DC}</math> (DC voltage – DC power) or Static <math>V_{DC} - I_{DC}</math> (DC voltage – DC current) characteristic (as appropriate) when operating as –Rectifier –Inverter</p>	<p>Diagram Diagram</p>	<p><b>DPD</b> <b>DPD</b> <b>DPD</b></p>						
<p>Details of rectifier mode control system, in block diagram form together with parameters showing transfer functions of individual elements.</p>	<p>Diagram</p>	<p><b>DPD</b></p>						
<p>Details of inverter mode control system, in block diagram form showing transfer functions of individual elements including parameters.</p>	<p>Diagram</p>	<p><b>DPD</b></p>						
<p>Details of converter transformer tap changer control system in block diagram form showing transfer functions of individual elements including parameters. (Only required for DC converters connected to the <b>GB Transmission System</b>.)</p>	<p>Diagram</p>	<p><b>DPD</b></p>						
<p>Details of AC filter and reactive compensation equipment control systems in block diagram form showing transfer functions of individual elements including parameters. (Only required for DC converters connected to the <b>GB Transmission System</b>.)</p>	<p>Diagram</p>	<p><b>DPD</b> <b>DPD</b></p>						
<p>Details of any frequency and/or load control systems in block diagram form showing transfer functions of individual elements including parameters.</p>	<p>Diagram</p>	<p><b>DPD</b></p>						
<p>Details of any large or small signal modulating controls, such as power oscillation damping controls or sub- synchronous oscillation damping controls, that have not been submitted as part of the above control system data.</p>	<p>Diagram</p>							
<p>Transfer block diagram representation of the reactive power control at converter ends for a voltage source converter.</p>	<p>Diagram</p>							

**NOTE:**

Users are referred to Schedules 5 & 14 which set down data required for all **Users** directly connected to the **GB Transmission System**, including **Power Stations**

**Annex 4 - JPC Evaluation Further Information**Appendix 1 (ALTERNATIVE)Data not specifically required for stability studies

The Data Registration Code comprises of 15 Schedules and is a summary of all data required under the Grid Code. In order for the TOs to fulfil their obligation under the Transmission Licence and GBSQSS to carry out stability studies, only a subset of this data will be required from Schedule 1 of the DRC. No data items are required from Schedules 2 to 15 of the DRC.

The following table is an extract from DRC schedule 1 and lists data that could be considered sensitive in respect of the generation market and are therefore specifically excluded from data transfer for transmission planning. None of these data items are considered essential for running transient stability studies. All remaining data in DRC schedule 1 may be exchanged for transmission planning studies.

DATA DESCRIPTION	UNITS	DATA CAT.
Performance Chart at <b>Generating Unit</b> stator terminals <b>Output Usable</b> (on a monthly basis)	MW	<b>SPD</b> <b>SPD</b>
<u>GOVERNOR AND ASSOCIATED PRIME MOVER PARAMETERS</u>		
<b>Option 1</b>		
<u>BOILER &amp; STEAM TURBINE DATA</u>		
Boiler time constant (Stored <b>Active Energy</b> )	S	<b>DPD</b>
HP turbine response ratio: (Proportion of <b>Primary Response</b> arising from HP turbine)	%	<b>DPD</b>
HP turbine response ratio: (Proportion of <b>High Frequency Response</b> arising from HP turbine)	%	<b>DPD</b>
<b>Option 2</b>		
<u>All Generating Units</u>		
Governor Deadband - Maximum Setting - Normal Setting - Minimum Setting	±Hz ±Hz ±Hz	<b>DPD</b> <b>DPD</b> <b>DPD</b>
<u>Steam Units</u>		

Reheater Time Constant	sec	DPD
Boiler Time Constant	sec	DPD
HP Power Fraction	%	DPD
IP Power Fraction	%	DPD
<b><u>Gas Turbine Units</u></b>		
Waste Heat Recovery Boiler Time Constant		
<b><u>UNIT CONTROL OPTIONS*</u></b>		
Maximum droop	%	DPD
Minimum droop	%	DPD
Maximum frequency deadband	±Hz	DPD
Normal frequency deadband	±Hz	DPD
Minimum frequency deadband	±Hz	DPD
Maximum Output deadband	±MW	DPD
Normal Output deadband	±MW	DPD
Minimum Output deadband	±MW	DPD
Frequency settings between which Unit Load Controller droop applies:		
Maximum	Hz	DPD
Normal	Hz	DPD
Minimum	Hz	DPD
Sustained response normally selected	Yes/No	DPD
<i>(Power Park Modules)<sup>6</sup></i>		
Performance Chart of a at <b>Power Park Module</b> at the connection point <b>Output Usable</b> (on a monthly basis)	MW	SPD SPD
<b>DC CONVERTER STATION DATA</b>		
<b>ACTIVE POWER TRANSFER CAPABILITY</b> (PC.A.3.2.2)		
Import MW available in excess of <b>Registered Import Capacity</b> .	MW	SPD
Time duration for which MW in excess of <b>Registered Import Capacity</b> is available	Min	SPD
Export MW available in excess of <b>Registered Capacity</b> .	MW	SPD
Time duration for which MW in excess of	Min	SPD

<sup>6</sup> Note that some Power Park Module information is considered sensitive by manufacturers, because it may contain intellectual property. However, the JPC believes that this information could not be used to gain an advantage in the electricity market.

<b>Registered Capacity</b> is available		
LOADING PARAMETERS [ <b>PC.A.5.4.3.3</b> ]		
MW Export		
Nominal loading rate	MW/s	<b>DPD</b>
Maximum (emergency) loading rate	MW/s	<b>DPD</b>
MW Import		
Nominal loading rate	MW/s	<b>DPD</b>
Maximum (emergency) loading rate	MW/s	<b>DPD</b>

## Annex 5 - Copies of Comments received on the Proposed Amendment Report

This Annex includes copies of any representations received following circulation of the Proposed Amendment Report (circulated on [date], requesting comments by close of business on [date]).

Representations were received from the following parties:

No.	Company	File Number
1		CA021-AR-01