

BMU Capability and Price Submission Report

This report constitutes the publication of Holding Payment rates and other information as required by Clause 4.1.3.13A of the Connection and Use of System Code. The contents of the report include

- i. the available Response volume in respect of each applicable User's BM Unit(s) as indicated by :
 - Maximum Primary Response at 0.2Hz, 0.5Hz, 0.8Hz deviation from System nominal frequency of 50Hz
 - The amount of de-load from MEL required to deliver the maximum Primary Response at 0.2Hz, 0.5Hz, 0.8Hz deviation from System nominal frequency of 50Hz
 - Maximum Secondary Response at 0.2/0.2Hz, 0.5/0.5Hz deviation from System nominal frequency of 50Hz (NB : 0.2/0.2 Hz means the point on the Frequency Response matrix corresponding to 0.2Hz deviation under Primary Response and 0.2Hz deviation under Secondary Response).
 - The amount of de-load from MEL required to deliver the maximum Secondary Response at 0.2/0.2Hz, 0.5/0.5Hz deviation from System nominal frequency of 50Hz
 - Maximum High Frequency Response at 0.2Hz, 0.5Hz deviation from System nominal frequency of 50Hz
 - The amount of de-load from MEL required to deliver the maximum High Frequency Response at 0.2Hz, 0.5Hz deviation from System nominal frequency of 50Hz; and
- ii. The holding rates for Primary, Secondary and High Mandatory Frequency Response in respect of each applicable User's BM Unit(s) to apply in November 2005.

BMU Capabilities

MW Response Capability by BMU

UNIT	Primary Response (Max MWhrs)				Secondary Response (Max MWhrs)				High Frequency Response (Max MWhrs)					
	0.2Hz Unit De-load (MW)	0.5Hz Unit De-load (MW)	0.8Hz Unit De-load (MW)	0.2to2Hz Unit De-load (MW)	0.5to5Hz Unit De-load (MW)	0.2Hz Unit De-load (MW)	0.5Hz Unit De-load (MW)	0.8Hz Unit De-load (MW)	De-load (MW)					
ABT1W	40	250	72	250	72	250	48	250	120	250	38	185	55	185
ABT1H	40	250	72	250	72	250	48	250	120	250	38	185	55	185
ABT1G	40	250	72	250	72	250	48	250	120	250	38	185	55	185
BAGE-1	21	235	62	235	62	235	80	235	62	235	22	235	62	235
BAGE-2	3	17	12	17	12	17	4	17	9	17	2	17	5	17
BARKB2	30	215	63	215	63	215	36	215	63	215	23	63	69	69
BARK-1	20	145	42	145	42	145	24	145	58	145	22	45	46	15
BROG-1	16	126	32	126	32	126	16	126	40	126	14	76	34	76
BRYP-1	15	82	26	82	26	82	31	82	31	82	47	82	47	82
CDA-1	30	160	40	160	40	160	40	160	40	160	27	120	40	120
CLAC-1	3	37	6	37	6	37	3	37	6	37	0	37	6	37
CNPS-1	22	126	51	126	51	126	28	126	70	126	20	100	45	100
CNPS-2	22	126	51	126	51	126	28	126	70	126	20	100	45	100
CNPS-3	22	126	51	126	51	126	28	126	70	126	20	100	45	100
CNPS-4	22	126	51	126	51	126	28	126	70	126	20	100	45	100
COCK-1	16	80	35	80	35	80	27	80	21	80	2	58	5	58
COCK-2	16	80	35	80	35	80	27	80	21	80	2	58	5	58
COCK-3	16	80	35	80	35	80	27	80	21	80	2	58	5	58
COCK-4	16	80	35	80	35	80	27	80	21	80	2	58	5	58
CORB-1	18	60	30	60	30	60	22	60	39	60	22	24	40	0
CORB-2	18	60	30	60	30	60	22	60	39	60	22	24	40	0
COTPS-1	29	277	50	277	50	277	35	277	63	277	30	122	60	122
COTPS-2	29	277	50	277	50	277	35	277	63	277	30	122	60	122
COTPS-3	29	277	50	277	50	277	35	277	63	277	30	122	60	122
COTPS-4	29	277	50	277	50	277	35	277	63	277	30	122	60	122
CRUA-1	10	110	25	110	25	110	12	110	33	110	10	84	25	48
CRUA-2	10	110	25	110	25	110	12	110	33	110	10	84	25	48
CRUA-3	10	110	25	110	25	110	12	110	33	110	10	84	25	48
CRUA-4	7	30	18	30	18	30	10	30	25	30	7	20	18	5
CRUA-5	7	30	18	30	18	30	10	30	25	30	7	20	18	5
DAMC-1	64	380	136	380	136	380	80	380	180	380	60	290	180	128
DESP-1	20	180	60	180	60	180	22	180	60	180	24	96	52	96
DERW-1	13	90	35	90	35	90	16	90	40	90	16	90	32	72
DIDCB5	56	285	80	285	80	285	76	285	150	285	68	120	140	45
DIDCB6	64	203	100	203	100	203	60	203	100	203	115	130	73	130
DIDC1	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DIDC2	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DIDC3	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DIDC4	42	225	85	225	85	225	24	225	62	120	24	73	60	147
DIND-1	14	138	39	138	39	138	18	138	36	138	14	118	36	88
DIND-2	14	138	39	138	39	138	18	138	36	138	14	118	36	88
DIND-3	14	138	39	138	39	138	18	138	36	138	14	118	36	88
DIND-4	14	138	39	138	39	138	18	138	36	138	14	118	36	88
DIND-5	14	138	39	138	39	138	18	138	36	138	14	118	36	88
DIND-6	14	138	39	138	39	138	18	138	36	138	14	118	36	88
DRAXX-1	68	345	100	345	100	345	64	345	100	345	60	225	70	225
DRAXX-2	68	345	100	345	100	345	64	345	100	345	60	225	70	225
DRAXX-3	68	345	100	345	100	345	64	345	100	345	60	225	70	225
DRAXX-4	68	345	100	345	100	345	64	345	100	345	60	225	70	225
DRAXX-5	68	345	100	345	100	345	64	345	100	345	60	225	70	225
DRAXX-6	68	345	100	345	100	345	64	345	100	345	60	225	70	225
EECL-1	20	153	28	153	28	153	13	153	38	153	18	106	28	106
EGSP-1	45	205	83	205	83	205	49	205	110	205	33	95	60	95
EGSP-2	45	205	83	205	83	205	49	205	110	205	33	95	60	95
EGSP-3	45	205	83	205	83	205	49	205	110	205	33	95	60	95
EGSP-4	45	205	83	205	83	205	49	205	110	205	33	95	60	95
ERRO-1	1	21	1	21	1	21	1	21	5	21	1	17	1	17
ERRO-2	1	21	1	21	1	21	1	21	5	21	1	17	1	17
ERRO-3	1	21	1	21	1	21	1	21	5	21	1	17	1	17
FASH-1	0	15	1	15	1	15	1	15	2	15	0	15	1	12
FASH-2	0	15	1	15	1	15	1	15	2	15	0	15	1	12
FASH-3	0	15	1	15	1	15	1	15	2	15	0	15	1	12
FAWL1	36	244	77	244	77	244	10	244	10	244	40	98	91	145
FAWL3	36	244	77	244	77	244	10	244	10	244	40	98	91	145
FAWL4	36	244	77	244	77	244	10	244	10	244	40	98	91	145
FELL-1	9	63	21	63	21	63	10	63	24	63	9	63	22	63
FERR-1	25	150	45	150	45	150	30	150	60	150	34	80	59	150
FERR-2	25	150	45	150	45	150	30	150	60	150	34	80	59	150
FERR-3	25	150	45	150	45	150	30	150	60	150	34	80	59	150
FERR-4	25	150	45	150	45	150	30	150	60	150	34	80	59	150
FFES-1	10	35	27	35	27	35	9	35	22	35	4	27	6	27
FFES-2	10	35	27	35	27	35	9	35	22	35	4	27	6	27
FFES-3	10	35	27	35	27	35	9	35	22	35	4	27	6	27
FFES-4	10	35	27	35	27	35	9	35	22	35	4	27	6	27
FIDL-1	13	205	23	205	23	205	10	205	40	147	30	147	50	147
FIDL-2	13	205	23	205	23	205	10	205	40	147	30	147	50	147
FIDL-3	13	205	23	205	23	205	10	205	40	147	30	147	50	147
FIDL-4	13	205	23	205	23	205	10	205	40	147	30	147	50	147
FNL-1	0	14	1	14	1	14	1	14	2	14	0	14	1	11
FONE-1	6	60	13	60	13	60	11	60	27	60	5	30	11	30
FONE-2	6	60	13	60	13	60	11	60	27	60	5	30	11	30
GRAU-1	43	485	100	485	100	485	60	485	140	485	33	0	60	345
GRAU-2	43	485	100	485	100	485	60	485	140	485	33	0	60	345
GRAU-3	43	485	100	485	100	485	60	485	140	485	33	0	60	345
GRAU-4	43	485	100	485	100	485	60	485	140	485	33	0	60	345
GRAB-1	0	6	0	6	0	6	0	6	1	6	0	6	0	6
GRAB-2	0	6	0	6	0	6	0	6	1	6	0	6	0	6
GYAR-1	17	176	42	176	42	176	24	176	60	176	17	176	42	176
HUMR-1	30	330	75	330	75	330	45	330	113	330	30	257	75	220
IND-1	12	102	31	102	31	102	13	102	34	102	12	72	30	72
IRNPS-1	35	125	45	125	45	125	45	125	68	125	28	125	42	185
IRNPS-2	35	125	45	125	45	125	45	125	68	125	28	125	42	185
IRNPS-3	35	125	45	125	45	125	45	125	68	125	28	125	42	185
IRNPS-4	35	125	45	125	45	125	45	125	68	125	28	125	42	185
KEAD-1	36	300	78	300	78	300	62	300	128	300	38	190	84	190
KILLPS-1	8	225	10	225	10	225	10	225	12	225	4	150	15	150
KILLPS-2	8	225	10	225	10	225	10	225	12	225	4	150	15	150
KILNS-1	7	290	84	290	84	290	42	290	114	290	18	104	45	104
KIND-1	32	115	60	115	60	115	25	115	60	115	27	115	55	65
KIND-2	32	115	60	115	60	115	25	115	60	115	27	115	55	65
KIND-3	32	115	60	115	60	115	25	115	60	115	27	115	55	65
KIND-4	32	115	60	115	60	115	25	115	60	115	27	115	55	65
KLNA-1	24	126	50	126	50	126	34	126	70	126	22	81	34	81
LABR-1	40	230	64	230	64	230	66	230	130	230	60	120	60	120
LITTD1	57	485												

Effective 01-Jan-06

	Primary	Secondary	High
ABTH7	3.03	3.91	0.63
ABTH8	3.03	3.91	0.63
ABTH9	3.03	3.91	0.63
BAGE-1	2.52	2.92	0.75
BAGE-2	2.52	2.92	0.75
BARK-1	3.94	3.74	1.94
BARKB2	3.94	3.74	1.94
BRGG-1	22	14.4	12
BRYP-1	3.85	2.52	2.7
CDCL-1	4.5	4.5	1.5
CNQPS-1	4.5	4.5	3.5
CNQPS-2	4.67	4.67	3.5
CNQPS-3	4.83	4.83	3.5
CNQPS-4	5	5	3.5
COCK-1	5.9	5.9	1.22
COCK-2	5.9	5.9	1.22
COCK-3	5.9	5.9	1.22
COCK-4	5.9	5.9	1.22
CORB-1	4.5	4.5	1.4
COSO-1	5.22	5.31	3.59
COTPS-1	6.95	4.05	1
COTPS-2	7	4.15	1
COTPS-3	6.96	4.1	1
COTPS-4	6.5	4	1
CRUA-1	3.37	3.9	1.22
CRUA-2	3.37	3.9	1.22
CRUA-3	3.37	3.9	1.22
CRUA-4	3.37	3.9	1.22
DAMC-1	3.75	0.06	1.3
DEEP-1	5.9	2	4
DERW-1	4.01	4.01	1.22
DIDC1	2.66	3.55	0.56
DIDC2	2.66	3.55	0.56
DIDC3	2.66	3.55	0.56
DIDC4	2.66	3.55	0.56
DIDCB5	5.8	0.49	3.16
DIDCB6	4.8	0.49	3.16
DINO-1	4.9	3	2
DINO-2	4.9	3	2
DINO-3	4.9	3	2
DINO-4	4.9	3	2
DINO-5	4.9	3	2
DINO-6	4.9	3	2
DRAXX-1	1	5.27	4.73
DRAXX-2	1	5.27	4.73
DRAXX-3	1	5.27	4.73
DRAXX-4	1	5.27	4.73
DRAXX-5	1	5.27	4.73
DRAXX-6	1	5.27	4.73
EECL-1	4.5	4.5	2.06
EGGPS-1	2.45	3.14	0.51
EGGPS-2	2.45	3.14	0.51
EGGPS-3	2.45	3.14	0.51
EGGPS-4	2.45	3.14	0.51
ERRO-1	100	100	100
ERRO-2	100	100	100
ERRO-3	100	100	100
FASN-1	200	200	200
FASN-2	200	200	200
FASN-3	200	200	200
FAWL1	3.2	4.09	0.65

FAWL3	3.2	4.09	0.65
FAWN-1	5.68	0.58	1.37
FELL-1	1.9	1.9	0.44
FERR-1	3	4	10
FERR-2	4	5	15
FERR-3	5	6	20
FERR-4	6	7	25
FFES-1	4.9	3	2
FFES-2	4.9	3	2
FFES-3	4.9	3	2
FFES-4	4.9	3	2
FIDL-1	3	4	10
FIDL-2	4	5	15
FIDL-3	5	6	20
FIDL-4	6	7	25
FINL-1	50	50	50
FOYE-1	50	50	50
FOYE-2	50	50	50
GRAI-1	4.25	4.25	1.4
GRAI-3	4.25	4.25	1.4
GRAI-4	4.25	4.25	1.5
GRMO-1	100	100	100
GYAR-1	2.8	2.5	2
HUMR-1	100	100	100
INDQ-1	165	165	165
IRNPS-1	4.93	4.93	1.4
IRNPS-2	5.04	5.04	1.5
KEAD-1	4.5	5.5	20
KILLPG-1	4.5	4.5	1.4
KILLPG-2	4.5	4.5	1.45
KILNS-1	15.68	10.26	5.4
KINO-1	4.44	4.44	1.4
KINO-2	4.56	4.56	1.5
KINO-3	4.68	4.68	1.6
KINO-4	4.8	4.8	1.7
KLYN-A-1	24.75	16.2	9.6
LBAR-1	4.8	0.49	1.16
LITTD1	3.97	5.89	1.71
LITTD2	3.97	5.89	1.71
LITTD3	3.97	5.89	1.71
LOAN-1	5.71	5	1.22
LOAN-2	5.71	5	1.22
LOAN-3	5.71	5	1.22
LOAN-4	5.71	5	1.22
MEDP-1	4	5	15
PEHE-1	2.4	2.56	0.85
PEHE-2	3.8	2.89	0.85
PETEM1	3.3	3.2	2.55
RATS-1	5.88	5.88	1.4
RATS-2	5.91	5.91	1.5
RATS-3	5.94	5.94	1.6
RATS-4	6	6	1.7
ROCK-1	5.22	5.31	3.59
ROOS-1	22	14.4	12
RUGPS-6	4.8	3	2
RUGPS-7	4.9	3	2
RYHPS-1	3.4	3.5	1.3
SCCL-1	5	4	6
SCCL-2	5	4	6
SCCL-3	5	4	6
SEAB-1	2.65	2.65	0.43
SEAB-2	4	4	2
SHBA-1	4.95	2.5	3.5
SHBA-2	11.28	7.38	4.2
SHOS-1	3.4	3.5	1.3

SHOT-1	6.9	9.06	1.44
SIZB-1	25.63	43.18	42.65
SIZB-2	25.63	43.18	42.65
SLOY-1	100	100	100
SLOY-2	100	100	100
SLOY-3	100	100	100
SLOY-4	100	100	100
SPLN-1	14.99	14.99	14.99
SUTB-1	9	5.2	1.2
TESI-1	9,999.00	9,999.00	9,999.00
TESI-2	9,999.00	9,999.00	9,999.00
TILB-7	2.66	3.55	1.56
TILB-8	2.66	3.55	1.56
TILB-9	2.66	3.55	1.56
TILB10	2.66	3.55	1.56
USKM-13	2.21	1.94	0.59
USKM-14	2.21	1.94	0.59
USKM-15	2.21	1.94	0.59
WBUPS-1	6.65	5.48	0.81
WBUPS-2	6.65	5.48	0.81
WBUPS-3	6.65	5.48	0.81
WBUPS-4	6.65	5.48	0.81